

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ *school/2782*

Dated:- *27/07/12*

FIRE SAFETY CERTIFICATE

Certified that the *Little Star Convent School, Paras Ram Enclave*
Bazari, Delhi 110084 located at *Paras Ram Enclave, Bazari, Delhi*
..... comprised of *Two blocks, one having ground + one floor & 11 and 9 floor only*
by *Little Star Convent School* occupied
No. *F 6/DFS/MS/07/3534* was issued NOC vide this office letter
Dated: *21/11/07* The premises was re-inspected by the
officer concerned of this department on *03-07-2012* and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Educational with effect from *27/07/12* for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *27/07/12* at New Delhi.

26/7
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. *The Manager,*
Little Star Convent School,
Paras Ram Enclave
Bazari, Delhi
2. *The Addl. Officer (Edu)*
M.C.D. (North)
Civic Centre
Minister Rd. N-Delhi

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NOC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building Little star convent school, Paras Ram Enclave, Burari, Delhi.
2. Type of Occupancy Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DPS/ms/07/3534 Dated: 21-11-2007
5. Fire Safety directives letter No : Director Edun, 262-362 dt. 17-1-2005
6. Date of inspection 03/7/2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers sh. satender Kumar Tayagi.
from the building side :
9. Year of Construction 2002 (G+1) 2 blocks - 1) G+1=1
10. Applicant's letter No. LSCS/05/012 dt. 21-5-2012 (1) ground floor only

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular Dir. Edun. Requirement 17/1/2005</u>	Provided at site	Remarks MR/NMR
1	Access to building		<u>(old case)</u>	
	• Road width	<u>Accessible</u>	<u>5 m</u>	<u>m/R</u>
	• Gate width		<u>N/A</u>	
	• Width of internal road		<u>N/A</u>	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2</u>	<u>2</u>	<u>m/R</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>m/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>-</u>
	b. Width of staircases	<u>1.5 m</u>	<u>1.08 m (both)</u>	<u>m/R (old case)</u>
	• Upper Floors	<u>1.5 m</u>	<u>-do-</u>	<u>m/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	
	c. Protection of exits		<u>N/R</u>	
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace		<u>M/R</u>	
	g. Width of Corridor		<u>-</u>	
	h. Door Size	<u>1 m</u>	<u>1 m</u>	<u>m/R</u>

3	Compartmentation.				NIR	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 					
4	Smoke Management System.				NIR	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour				
5	Fire Extinguishers					
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	300 M ² covered order for one ABC or CO ₂ (2.5kg) ISI marked	4 ABC, CO ₂ yes		MIR MIR MIR	
6	First-Aid Hose Reels.					
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one provided provided		MIR MIR MIR	
7	Automatic fire detection and alarming system.				NIR	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 					
8	MOEFA				NIR	
9	Public Address System.				NIR	
10	Automatic Sprinkler System.				NIR	
	<ul style="list-style-type: none"> • Basement 					

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants		N/A	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.		N/A	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.		N/R	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		225 Lt./min	provided	M/R (old case)
		40 m	provided	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		N/R	

Little Star Convent school, Buzassi

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2500 Lts.	2500 Lts.	N/A (old case)
15	Exit Signage.		N/A	
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		N/A	
18	Refuge Area.		N/A	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		N/A	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

D.O. (N/A)

ADDER:V. spoken pl. 10/7

Shyama Lal
06/7/2012
(SHYAMA LAL)
Asstt. Divn. Officer

D.O. floor only, G+1 floor having two staircase p' Shyama Lal
ADDER:V. 10/7