

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/school/2012/2817

Dated: 31/07/2012

FIRE SAFETY CERTIFICATE

Certified that the **Prabhu Dayal Public School** located at Dakshini Block A, Shalimar Bagh, Delhi-110088, comprised of Ground + 02 upper floors, only was issued NOC vide this office letter no. **F.6/DFS/MS/2009/2117 dated 15/07/2009**. The premises was re-inspected by the officer concerned of this department on 21.06.2012 in the presence of **Mr. A.K. Sharma, Principal** and observed that all the fire safety and fire prevention arrangement as provided in the premises is found in good working condition and there is no additional construction. The premises have deemed complied with requirements under Rule 33 of Delhi Fire Service Rules, 2010 and building/premises is fit for occupancy under Educational class with effect from 31/07/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....31/07/12.....at New Delhi by

31/7
Chief Fire Officer
Delhi Fire Service
o/d

Copy to:

1. **Mr. A.K. Sharma, Principal**
Prabhu Dayal Public School
Dakshini Block A, Shalimar Bagh, Delhi-110088
2. The Director of Education, Old Secretariat, Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

Rambhadr...

May kindly see the letter No 164 dated 17.04.2012 received from Principal, Prabhu Dayal Public School regarding the issue of NOC for Prabhu Dayal Public School, Dakshini Block A, Shalimar Bagh Delhi-110088 from fire safety point of view and was issued NOC vide this office letter No. F.6/DFS/MS/10/893 dated 09.02.2010. Premises was inspected by the ADO (Wazirpur) on 21.06.2012 & observed that the building is comprised of ground plus two upper floors only and having plot area 6000 sq/ meter and covered area is 2200 sq. meter.

The point wise compliance of the safety recommendations as per Delhi Fire Service Act, 2007 & Delhi Fire Service, Rules, 2010, are given below:

INSPECTION REPORT

Name & address of the building : Prabhu Dayal Public School, Shalimar Bagh
 Type of Occupancy : Renewal of School (Education)
 Type of Case : Renewal
 Details of previous NOC : F.6/DFS/MS/10/893 Dated 09.02.2010
 Fire Safety directives letter No. : DFS Act, 2007 & DFS Rules 2010
 Date of inspection : 21.06.2012
 Name of the Inspecting Officers : Sunil Rajmal Khokhar, ADO
 Name and designation of officers : Sunil A. K. Sharma
 from the building side : Principal
 Year of Construction : 1987
 Applicant's letter No. : 164 Dt. 17.04.2012

No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>—u—</u>	<u>—u—</u>	<u>—u—</u>
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	<u>03</u>	<u>05</u>	<u>MR</u>
	• Upper Floors	<u>—u—</u>	<u>—u—</u>	<u>MR</u>
	• Basement	<u>-</u>	<u>-</u>	<u>-</u>
b.	Width of staircases	<u>150 cms each</u>	<u>2 - 150 cms 3 - 130 cms.</u>	<u>MR</u>
	• Upper Floors	<u>—u—</u>	<u>—u—</u>	<u>—u—</u>
	• Basement	<u>-</u>	<u>-</u>	<u>-</u>
c.	Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>

d.	No. of continuous staircases to terrace	-	-	-
e.	Width of Corridor	1½ meters	2½ meters	MR
f.	Door size	1"		
3.	Compartmentation.	NA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System.	NA		
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers			
	• Total numbers	10	25	MR
	• Types		ABC Type	✓
	• IS marking	ISI marked	ISI Marked	✓
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	06 (Two each floor)	06	MR
	• Length of hose reel hose	30 m	30 m	✓
	• Nozzle diameter	5 mm	5 mm	✓
7.	Automatic fire detection and alarming system.	NA		
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooter's Location	-	-	-
8.	MOEFA	-	-	-

Public Address System.		-	-	-
Automatic Sprinkler system			NA	
<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		-	-	-
		-	-	-
		-	-	-
11. Internal Hydrants			NA	
<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		-	-	-
		-	-	-
		-	-	-
12. Yard Hydrants.			NA	
<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		-	-	-
		-	-	-
13. Pumping Arrangements.				
Ground Level				
➤ Discharge of main pump		-	-	-
➤ Head of Main pump		-	-	-
➤ Number of main pumps		-	-	-
➤ Jockey Pump out put		-	-	-
➤ Jockey pump head		-	-	-
➤ Standby pump out put		-	-	-
➤ Standby pump Head		-	-	-
➤ Auto Starting/Manual stopping		-	-	-
➤ Pump Hose Access		-	-	-
Terrace level				
➤ Discharge of pump	900 LPM & 180 LPM	900 LPM & 180 LPM		MR
➤ Head of the pump	40 mhrs	40 mhrs		→
➤ Power supply		-	-	-
➤ Auto Starting of pump		-	-	-

Captive Water Storage for fire fighting.

NA

Underground tank capacity

- Draw -off connection
- Fire service inlet
- Access to tank
- Overhead Tank Capacity

10000 litres

15000 litres

nil

15. Exit Signage.

16. Provision of Lifts

- Pressurization of Lift Shaft
- Pressurization of Lift lobby
- Communication In lift Car
- Fireman's Grounding Switch
- Lift Signage

NA

17. Standby power supply

18. Refuge Area

NA

- Total Area
- Location

NA

19. Fire Control Room

NA

- Detector System Panel
- Flow Switch Panel
- PA system Panel
- Batter backup
- Building Floor plans

20. Special Fire Protection Systems for Protection of special Risks, if any:

✓
The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓
Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number
.....


Signature of the Inspection Officer

Signature of the Inspection Officer

Name SHRI RAJMAL KHOKHAR

Name

Designation ADO

Disignation