

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO.F6/DFS/MS/GH/2012/283/

Dated: 03/08/12

FIRE SAFETY CERTIFICATE

Certified that M/s Rabbi guest house located at 1141, Haveli Sadar Sadoor, Matia Mahal, Jama Masjid, Delhi comprised of ground (Commercial use), first floor (03 rooms + reception), second floor (03 rooms) third floor (owners residence) and fourth floor (owners residence) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/3030 dated 15-10-2009. The premises was re-inspected by the officer concerned of this department on 25-07-2012 in the presence of Mohd. Ejazuddin, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 03/08/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 03/08/12 at New Delhi by.


118
**Chief Fire Officer
for Director
Delhi fire service**

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, M/s Rabbi guest house, 1141, Haveli Sadar Sadoor, Matia Mahal, Jama Masjid, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Rabbi Guest House, 1141, Haveli Sadar Sadok,
Mata Mohal, Jama Masjid, Delhi
2. Type of Occupancy : Lodging house
3. Type of Case : ~~New Case~~/ Renewal
4. Details of previous NOC : Letter No. FG/DFB/MS/GH/09/3030 Dated: 15/10/09
5. Fire Safety directives letter No : -
6. Date of inspection : 25/3/12
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO (HO)
8. Name and designation of officers from the building side : Mohd. Ejazuddin, Manager
9. Year of Construction : 2004
10. Applicant's letter No. : 31963/ Addl. e-p/Lic (H)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	PSS area	10-ft road 2.15 mt away from Main road	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	N/A	N/A	-
	b. Width of staircases			
	• Upper Floors	0.80 mt	0.88 - 1.00 mt	MR
	• Basements	N/A	N/A	-
	c. Protection of exits			
	• Fire check door	N/A	N/A	-
	• Pressurization	N/A	N/A	-
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-
	h. Door Size	N/A	N/A	-
		-	-	-
3	Compartmentation.	N/A	N/A	-

GF - Commercial
 1st floor - Reception + 03 rooms
 2nd floor - 03 rooms
 3rd & 4th floor - Owners residence

10

S/N

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	-
			N/A	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 06 • Types water CO₂, CO₂ • IS marking 	water CO ₂ - 3 CO ₂ - 3 ISI marked	provided provided provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	provided provided provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
8	MOEFA	N/A	N/A	-
9	Public Address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	-

J

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	N/A	N/A	-
		N/A	N/A	-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	-
		N/A	N/A	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		225 LPM	225 LPM	MR
		25 mt	25 mt	MR
		-	-	-
		-	starting switch provided near reception	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		2500 lts	2500 lts	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	N/A	N/A	-
		N/A	N/A	-

[Handwritten signature]

7/5

	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	-
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	-
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	-
17	Standby power supply	N/A	N/A	-
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-
	➤ Location	N/A	N/A	-
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	-
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	-
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	-
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	-
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ type fire extinguisher found provided near Elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew/grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name
Designation

Name M.K. CHATTOPADHYAY
Designation ADO (HO)

DO (CP) 21/07/12

DT