

NO. F6/MS/DFS/GH/2012/2833

DATED: 03/08/12

FIRE SAFETY CERTIFICATE

Certified that the M/S Shyama International Inn C-5/32 Safderjung Development Area New Delhi comprise of Basement(Storage), ground plus three upper floors(23 Guest Rooms) was granted N.O.C by this department wide letter no. F6/MS/DFS/GH/09/2264 Dt.27/07/2009.. The premises re-inspected by the officers concerned of Fire Service on 10/07/2012 in the presence of Mr. Umesh Singh and found that the said Guest House have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules,2010 and that the premises fit for occupancy class Lodging or Rooming House of Group-A " with effect from 03/08/12... for a period of **three years**, subject to conditions as mentioned below.

Issued on 03/08/12..... at New Delhi by


Chief Fire Officer
Delhi Fire Service
o/a

Copy To:-

1. Shyama International Inn C-5/32 Safderjung Development Area, New Delhi.
2. The Addl. Commissioner of Police (Lic.) first floors , Police Station, Defence Colony, New Delhi .

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigo.t.nic.in

INSPECTION REPORT

1	Name & address of the building	Shyama International Inn, C-5/32, Safdarjung Development Area, N Delhi		
2	Type of Occupancy	Residential & Lodging "A"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/GH/2009/2264 Dated 27/07/2009.		
5	Fire safety directives letter No	No		
6	Date of inspection	10/7/2012		
7	Name of the inspecting Officers :	ADO S.S.Kaushik <i>Do. Dharmpal Bhardwaj</i>		
8	Name and designation of officers from the building side	Mr. Umesh Singh		
		Basement, Ground+3 Upper floors 23 guest Rooms.		
9	Year of construction	1981		
10	Applicant's letter No.	39867/Add. C.P/Lic.(H)	20/06/2012	Old Case
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/Old case	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	18 Mtrs	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Old case	Provided 2Nos	MR
	2. basements	Old case	Provided 2Nos	MR
	b. Width of staircase			
	1. Upper floors	Required	Provided 2Nos <i>1.22m each</i>	MR Old Case
	2. basements	Required	Provided 2Nos <i>1.50 & 1.20</i>	MR Old case
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Reqused	2 Nos. Stairs Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	Exhust Fans Provided	MR
	upper floors		Natural vantilation	MR
5	Fire Extinguishers			
	total numbers		15 Nos	MR
	Types		ABC, Co2 & W.Co2	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR

7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	Old case	180 LPM Provided	MR
	b. head of the pump	Old case	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 ltrs.	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	Rrquired	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.		Not Required	
	total area			
	location			

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of ne minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules,2010.Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the Inspecting Officer

Name

Designation

S.S. Kaushik

A.D.O. (BCP)