

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/GH/2012/ 2941

Dated: 09/08/12

**FIRE SAFETY CERTIFICATE**

Certified that M/s Amreena guest house located at 953, Gali Shyamlal, Bazar Matia Mahal, Jama Masjid, Delhi comprised of ground floor(04 guest rooms + reception), first floor (04 guest rooms), second floor (04 guest rooms) and terrace floor (02 rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/3092 dated 26-10-2009. The premises was re-inspected by the officer concerned of this department on 25-07-2012 in the presence of Mr.Obesh Tariq, owner of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 09/08/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 09/08/12 at New Delhi by.

  
Chief Fire Officer  
for Director  
Delhi fire service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi
2. The Manager, M/s Amreena guest house, 953, Gali Shyamlal, Bazar Matia Mahal, Jama Masjid, Delhi

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Old case

**INSPECTION REPORT**

1. Name & address of the building : Amreena Guest House, 953, Gali Shyam Lal, Bagas Malika Mahal, Jama Masjid, Delhi.
2. Type of Occupancy : Lodging house
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FE/DFs/MS/GH/09/3092 Dated: 26/10/2009
5. Fire Safety directives letter No : -
6. Date of inspection : 25/2/12
7. Name of the Inspecting Officers : M.K.Chattopadhyay
8. Name and designation of officers from the building side : Mr. Obesh Tariq, owner
9. Year of Construction : 1993
10. Applicant's letter No. : 43101/Addl.C.P/(Lr)(H) dated 9/2/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	pss area	10 ft Gali of 15 mt away from bit road	MR
	• Gate width	-	Directly accessible from the Street	MR
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case.
	• Basements	N/A	N/A	-
	b. Width of staircases	-	-	-
	• Upper Floors	0.80 mt	0.90 mt	MR
	• Basements	N/A	N/A	-
	c. Protection of exits	N/A	N/A	-
	• Fire check door	N/A	N/A	-----
	• Pressurization	N/A	N/A	-----
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	N/A	N/A	-----
		N/A	N/A	-----
3	<b>Compartmentation.</b>	N/A	N/A	-----

GF - 04 guest rooms + reception  
 1st - 06 guest rooms  
 2nd - 04 guest rooms  
 terrace floor - 02 rooms

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A	-----
			N/A	-----
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers 06</li> <li>• Types water CO<sub>2</sub> CO<sub>2</sub></li> <li>• IS marking</li> </ul>	water CO <sub>2</sub> - 3 CO <sub>2</sub> - 3 ISI marked	provided provided provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 30 m 5 mm	provided provided provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	----- ----- ----- ----- -----
8	<b>MOEFA</b>	N/A	N/A	-----
9	<b>Public Address System.</b>	Required	provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	----- ----- -----
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	N/A	N/A	-----

g



	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	N/A	N/A	-----
17	<b>Standby power supply</b>	Required	6 KVA	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO <sub>2</sub> type fire extinguisher provided near Elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew/~~grant~~ Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name

Designation

DO (CO) - 27/07/12

Signature of the Inspecting Officer

Name (M.K.CHATTOPADHYAY)

Designation ADO (HQ)

*(Handwritten signature)*