

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001

No: F 6/DFS/MS/2012/ Hospital/ 2876

Dated:- 07/08/12

FIRE SAFETY CERTIFICATE

Certified that the Bhogwati Hospital Sect-13 Rohini Delhi 85
located at Sect-13 Rohini Delhi
comprised of Basement + 9 + 3 upper floors
by Sarvodaya Health Foundation occupied
No. F-6/DFS/MS/hosp/08/146-P Dated: 21.6.2008 was issued NOC vide this office letter
officer concerned of this department on 17.7.12 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Institutional (Hospital) with effect from 07/08/12 for a period of
Three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 07/08/12 at New Delhi.

618
Chief Fire Officer
Delhi Fire Service

dk shy

Copy to:-

1. The Authorized Signatory
Bhogwati Hospital
Sect-13
Rohini Delhi

2.
.....
.....
.....

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants In case of emergency.
 3. All the fire fighting equipment shall be maintained In perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated In any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building Bhagwati Hospital, Sect. 13, Rohini, Delhi-85.
2. Type of Occupancy Institutional
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DES/MS/Hosp/08/1469 Dated: 2-6-2008
5. Fire Safety directives letter No : NBC
6. Date of inspection 17-7-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers Dr. Ramesh Pamnani.
from the building side :
9. Year of Construction 2003. (B+Gr.+3)
10. Applicant's letter No. NIL dated 29-5-2012.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building	(Old case)		
	• Road width	06 m	18 m	M/R
	• Gate width	05 m	Provided	M/R
	• Width of internal road		N/A	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	3 stair 1 Ramp } 4	Provided	M/R
	• Upper Floors	2 Stair	2 Stair	M/R
	• Basements	1 stair 1 Ramp } 2	1 Stair 1 Ramp	M/R
	b. Width of staircases			(old case)
	• Upper Floors	2 m	2.07 m	M/R
	• Basements	2 m	1.10 m Ramp - 2.60 m 3 stair - 1.48 m	M/R
	c. Protection of exits			
	• Fire check door	R	Provided	M/R
	• Pressurization		N/R	
	e. No. of continuous staircases to terrace	2	2	M/R
	g. Width of Corridor		2 m	M/R
	h. Door Size	0.2 m	1.8 m	M/R old case

Bhagwati Hospital, Sect-13, Rohini.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	R	Provided	MIR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	R	Provided	MIR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	—	—	—
	<ul style="list-style-type: none"> • Water Curtain 	—	—	—
	<ul style="list-style-type: none"> • Fire Dampers 	—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	EXIST ^{MIR} Fans provided	MIR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	52	Provided	MIR
	<ul style="list-style-type: none"> • Types 	CO ₂ , ABC, W.CO, AFFF	CO ₂ , ABC, W.CO, AFFF	MIR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	yes	MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one	Provided	MIR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MIR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MIR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke detector	Provided	MIR
	<ul style="list-style-type: none"> • Location of Main Panel 	Ground floor	Provided	MIR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	—	—	—
	<ul style="list-style-type: none"> • Alternate source of power 	R	Provided	MIR
	<ul style="list-style-type: none"> • Hooters' Location 	Corridors	Provided	MIR
8	MOEFA	R	Provided	MIR
9	Public Address System.	R	Provided	MIR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	Provided	MIR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		N/R	
			N/R	
11	Internal Hydrants		N/R	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.		N/R	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head (Terrace) Jockey. ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		N/R	
			/	
		180 Lts./minit.	180 Lts./minis	M/R
		40 m	provided	M/R
			N/R	
		450 Lts./minit	Provided	M/R
		40 m	provided	M/R
		R	provided	M/R
		R	Provided	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	25000 Lts.	25000 Lts.	M/R
			N/R	

Bhagwati Hospital, Sect-13, Rohini, Delhi.

	➤ Fire service inlet		N/A	
	➤ Access to tank	R	provided	
	• Overhead Tank capacity	12500 Lts.	provided	MIR
15	Exit Signage.	R	provided	MIR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	Nil	MIR
	• Pressurization of Lift lobby	N/A	Nil	MIR
	• Communication In lift Car	R	Alarm provided	MIR
	• Fireman's Grounding Switch	R	provided	MIR
	• Lift Signage	R	provided	MIR
17	Standby power supply	R	provided	MIR
18	Refuge Area.		N/A	
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel	R	provided	MIR
	• Flow Switch Panel	R	provided	MIR
	• PA System Panel	R	provided	MIR
	• Batter backup	R	provided	MIR
	• Building Floor Plans	R	provided	MIR
20	Special Fire Protection Systems for Protection of special Risks, if any:		Nil	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers... X

D.O-N/K

CF6

2577.

General
20/11/2012
(SHYAM LAL)
Assist. Divm. Officer