

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No: F6./DFS/MS/GH/2012/ 2861

Dated: 06/08/12

FIRE SAFETY CERTIFICATE

Certified that the **D Inn** Guest House located at 3685-89, 3691-92 & 3703/XV, Gali Dariba Pan, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + 01 office + 02 guest rooms), 1st floor to 3rd floor (05 Guest rooms at each floor) and Terrace floor (mumty, water tanks & open terrace) Total 17 Guest Rooms owned / occupied by M/s D Inn Guest House have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 22-06-2012 in the presence of Mr. D.D. Sharma (manager) and that the building / premises, is fit for occupancy class Group A Sub Division A-I Lodging or Rooming Houses with effect from ~~06/08/12~~ for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued ..06/08/12.. at New Delhi by.


613
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.),
First Floor, P.S. Defence Colony, New Delhi – 110049
2. M/s **D Inn** Guest House located at 3685-89, 3691-92 & 3703/XV, Gali Dariba Pan, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building: D. Inn guest House, 3685-89, 3691-92, & 3703/XV, Gali, Dariba Pan Pakar Ganj, New Delhi-110055.
2. Type of Occupancy: Residential (Guest house)
3. Type of Case: new
4. Details of previous NOC: Letter No - N.A -
5. Fire Safety directives Letter No.: - N.A -
6. Date of inspection: 18-07-2012
7. Name of the Inspecting Officer: Dharmvir Singh Yadav.
8. Name and designation of Officer from the building side: Shri D.D. Sharma (Manager)
9. Year of Construction: 2007
10. Applicant's letter No.: 13536-37/Addl.C.P./Lic.(H) dated New Delhi the 09-03-2012

P.S.S Area

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N.A	In side 6' wide Gali one hose length from main A.K Road -	M.R
	• Gate width	N.A	1.50 mtrs	M.R
	• Width of internal road	N.A	N.A	N.A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	one	one	M.R
	• Upper floors	one	one	M.R
	• Basements	N.A	N.A	N.A
	b. Width of staircases			
	• Upper floors	01.25 mtrs	1.33 mtrs to 1.50 mtrs	M.R
	• Basements	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No of continuous staircase to terrace		one	M.R

contd:-

D. 9m guest house, 3685-89 3691-92 &
 3703/XV, Gali Daula Pan
 Pahal Garh, New Delhi-110055
 P.S. Area

e. Width Of Corridor	—	01-28 mtrs	M.R
f. Door Size	—	225 M.M X 81 M.M	M-R
Compartmentation			
• Fire check door	N.A	N.A	N.A
• Sealing of electrical shafts	N.A	N.A	N.A
• Fire Rating of shaft door	N.A	N.A	N.A
• Water Curtain	N.A	N.A	N.A
• Fire Dampers	N.A	N.A	N.A
Smoke managements System			
• Basements	30 a/c per hour	N.A	N.A
• Upper floors	12 a/c per hour	Natural ventilation	M.R
Fire Extinguishers			
• Total numbers	08 (Eight)	08 (Eight)	M.R
• Types	—	A.B.C Type 5 kg W.Co2 Type 5 Liter	M.R M.R
• IS marking	ISI marked	Yes	M.R
First - Aid Hose Reels			
• Total numbers on each floor	one	one	M-R
• Length of hose reel hose	30 mtrs	30 mtrs	M.R
• Nozzle diameter	05 MM	05 MM	M.R
Automatic fire detection and alarming system			
• Type of detectors			
• Location of Main Panel		N.A	
• Location of Repeater Panel			
• Alternate source of power			
• Hooters' Location			
MOEFA	yes	Provided	M.R
Public Address System	yes	Provided	M.R
Automatic Sprinkler System			
• Basements	N.A	N.A	N.A
• Upper Floor	N.A	N.A	N.A

contd:-

D. Jang guest house 3685-89, 3691-92 & 3703/80
 Gali Desiba Pan, Palah Garh, New Delhi
 110055

P.S. Alee

	• Sprinkler above false ceiling	N.A	N.A	N.A
Internal Hydrants				
	• Size of riser/down-comer	N.A	N.A	N.A
	• Number of hydrants per floor	N.A	N.A	N.A
	• Hose Box	N.A	N.A	N.A
12.	Yard Hydrants			
	• Total number of hydrants	N.A	N.A	N.A
	• Hose Box	N.A	N.A	N.A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps		N.A	
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	• Terrace level	450 LPM	450 LPM	M.R
	➤ Discharge of pump	30 mtrs	30 mtrs	M.R
	➤ Head of the pump	yes	Provided	M.R
	➤ Power supply			
	➤ Auto starting of pump	yes	Provided	M.A
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity			
	➤ Draw of connection		N.A	
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity	2500 Ltrs.	2500 Ltrs.	M.R

contd :-

D. 2nd guest house,
 3685-89 3691-92 & 3703/XV
 Gali Sakiba Pur, Paloh Gary, New Delhi-110045
 PSE Area
 M.R

15	Exit Signage	yes	Provided	M.R
16	Provision of Lifts			
	> Pressurization of Lift Shaft	N.A	N.A	N.A
	> Pressurization of lift lobby	N.A	N.A	N.A
	> Communication in lift Car	yes	Provided	M.R
	> Fireman's Grounding Switch	—	Provided	M.R
	> Lift Signage	—	Provided	M.R
17	Standby power supply	yes	D.G. set	M.R
18	Refuge Area			
	> Total area		N.A	
	> Location			
19	Fire control room			
	> Detector system panel		N.A	
	> Flow Switch Panel			
	> PA System Panel			
	> Batter backup			
	> Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any;	—	N.A	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 issue ~~forthcoming~~ as noted at serial numbers

D.O. (Certificate)
 Signature of the Inspecting Officer

18-7-12
 Signature of the Inspecting Officer

Name Dr. Ram Vik Singh Yadav

Des. CF/THQ

Designation Assistant Div. Officer.