

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001**

No. G6/DFS/ans/2012/2921

Dated : 09/08/12

**FIRE SAFETY CERTIFICATE**

Certified that the **Motilal Nehru College** located at **Benito Juarez Marg, New Delhi-110021**, comprised of **Basement, Ground + 2 Upper Floor** owned/occupied by **Motilal Nehru College (Delhi University)**. The premises was inspected by the officer concerned of this department on **06/06/12** in the presence of **Mr. Ramdular Singh** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational Building** with effect from 09/08/12 -----for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 09/08/12 at New Delhi by.



Chief Fire Officer  
Delhi Fire Service

- Copy to:- (1) The Dy. Director,  
DDA, C-1, 2<sup>nd</sup> Floor, Vikas Sadan, INA, New Delhi.
- (2) Motilal Nehru College,  
Benito Juarez Marg, New Delhi-110021.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

216  
**INSPECTION REPORT**

1. Name & address of the building:- Motilal Nehru College, Benito Juarez Marg, New Delhi-110021.
2. Type of occupancy:- Educational Building
3. Type of case:- New
4. Details of previous NOC:- No
5. Fire safety directives No.- F6/DFS/MS/BP/96/1404 dated 25/06/96
6. Date of inspection:- 06/06/12
7. Name of the inspecting officer:- D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Mr. Ramdular Singh.
9. Year of construction:- 1989
10. Applicant's letter No:- MNC/BJM/36 dated 10/04/12 Basement, Ground +2 upper Floor.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	33 mtr.	Provided	MR
	2) Gate width	5 mtr.	5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	5 Nos.	5 Nos.	MR
	2. Basements	2 Nos.	2 Nos.	MR
	<b>B. Width of staircase</b>			
	1. Upper floors	1.20 mtr.	As per Directives 150cm x 130cm / 125cm x 120cm	MR
	2. Basements	1.20 mtr.	1.40, 1.50cm	MR
	<b>C. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
		two	two	MR
	<b>E. Width of corridor</b>			
		N/A	N/A	N/A
	<b>F. Door size</b>			
		1.20 mtr.	1.20 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	50 Nos.	MR
	2) Types		ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	Yes	four at each	MR



	2) Length of hose reel hose	30 m	floor	
	3) Nozzle diameter	5 mm	Yes	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
		NR	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	Yes	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	Yes	150 mm	MR
	2) Number of hydrants per floor	Yes	2 Nos.	MR
	3) Hose box	Yes	2 Nos.	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	Yes	9 Nos.	MR
	2) Hose box	Yes	9 Nos.	MR
13.	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM X 2	MR
	b) Head of pump	35 mtr.	35 mtr.	MR
	c) Power supply	Yes	D.G. set	MR
	d) Auto starting of pump	Yes	Yes	MR
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	50,000 ltrs.	50,000 ltrs.	MR
	a) Draw-off connection	Yes	Provided	MR
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	12,500 ltrs.	12,500 Ltr.	MR
15.	<b>Exit Signage.</b>			
		Yes	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Yes	Provided	MR

	e) Lift signage	Yes	Provided	MR
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj.

Designation:- Divisional Officer



Name:- S.S.Kaushik. 11/7/12

Designation:- Assistant Divisional Officer.

