

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F6/DFS/MS/EH/2012/2891

Dated: 07/08/12


FIRE SAFETY CERTIFICATE

Certified that the M/s Sagar Ratna Restaurants Pvt. Ltd. located at A-2/40, Rajouri Garden, New Delhi. The building comprised of ground floor plus one & half upper floors. The restaurant is running at first floor & half upper floor only. Above Restaurant was issued NOC vide this office letter No.F.6/DFS/MS/EH/2009/2688 dated 02/9/2009 based on circular No.F.6/DFS/MS/EH/2005/718 dated 04.11.2005 owned/occupied by the management of Sagar Ratna Restaurants Pvt. Ltd. have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 26.07.2012 in the presence of Sh. Sudhakar Maban(Manager). The building / premises is fit for occupancy class Group D assembly building Sub- Division D-6 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....07/08/12..... at New Delhi.

Copy to:-

1. The Manager
M/s Sagar Ratna Restaurants Pvt. Ltd.,
A-2/40/III, Rajouri Garden, New Delhi.


Chief Fire Officer
Delhi Fire Service



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Ground Floor plus 1 $\frac{1}{2}$ Floor

INSPECTION REPORT

1. Name & address of the building : Ms Sagar Ratna Restaurants Pvt Ltd, A-2/40/15, Rajouri Garden, New Delhi
2. Type of Occupancy : Group D, Sub Div D-6
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/EH/2009/2688 Date 02.09.2009
5. Fire Safety directives letter No : N/A
6. Date of inspection : 26.07.2012
7. Name of Inspecting Officer : D.O H.L. Anja & A.D.O P.S. Dahiya
8. Name and designation of officers : Sh. Sudhakar Mabian (Manager)
From the building side
9. Year of Construction : Before 2007
10. Applicant's letter No. : NIL dated 30.05.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	18mtr	MR
	• Gate width	-	106cm	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	MR
	• Basements	-	-	NO Basement
	b. Width of staircases			
	• Upper Floor	-	110cm, 82cm	MR, Being old case
	• Basements	-	-	NO Basement
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace			
		-	One	-
	e. Width of Corridor			
		-	140cm	-
	f. Door Size			
		-	170cm x 202cm	-
		-	77cm x 200cm	-
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	N/A	-	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	NO Basement
	• Upper floors		Natural Ventilation/ Exhaust fans	MR

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	10 Nos	Provided	MR
	• Types	ABC, CO ₂ , DCP	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	N/A	-	-
	• Location of Repeater Panel	N/A	-	-
	• Alternate source of power	-	D.G. Set of 75kva	-
	• Hooters' Location	-	-	-
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	NO Basement
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	100 M.M	100 M.M	MR
	• Number of hydrants per floor	One	One	MR
	• Hose Box	- do -	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	-	-
	• Hose Box	N/A	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-
		N/A	-	-

A-2/40 , Rajouri Garden,
New Delhi.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		Required	450 LPM, 180 LPM	MR
		- do -	30 M Each	MR
		Required	Provided	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		-	Provided	MR
		-	-	-
		-	5000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	NO Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} ~~grant~~ Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The restaurant running at first floor of the building comprised of Ground floor & one & half upper floors with two staircases of width 110cm & 82cm respectively. The seating capacity of restaurant is 140 as informed by the owner. Exhaust fans are provided in the kitchen for proper ventilation.


Signature of Inspecting Officer

Name H.L. Aneja

Designation Divisional Officer


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer