

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2012 / GH / 2948

Dated 09/08/12

FIRE SAFETY CERTIFICATE

Certified that the "Sindh Palace" Guest House, located at 7966, Arakashan Road, Pahar Ganj, New Delhi, comprised of Ground + Four upper floors having 09 guest rooms (Ground floor has Reception + 01 guest room, First to Fourth floor has 02 guest rooms at each floor) was granted NOC by this department vide letter No F 6 / DFS / MS / GH /2009/ 2212 dated 23.07.2009. The premise was re-inspected by the officer concerned of this department on 06.08.2012 in the presence of Mr. Suresh found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from ..09/08/12.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..09/08/12..... at New Delhi.



Chief Fire Officer
Delhi Fire Service

etc
man

Copy to: -

1. The Owner, "Sindh Palace" Guest House, located at 7966, Arakashan Road, Pahar Ganj, New Delhi.
2. The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. This NOC is for Guest Rooms only.

add case
SP area

INSPECTION REPORT

1. Name & address of the building: M/S Sindh Palace, 7966, A-K Road.
Paharganj.
2. Type of Occupancy: Residential (Guesthouse)
3. Type of Case: old (Renewal)
4. Details of previous NOC: Letter No FG/DFS/MS/SH/2009/2012 dated 20/07/09
5. Fire Safety directives Letter No.: N/A
6. Date of inspection: 6/8/12
7. Name of the Inspecting Officer: ATUL GARY & D-S Yadav
8. Name and designation of Officer: Mr Suresh
from the building side
9. Year of Construction: Before 2003 (As per title m/fil)
10. Applicant's letter No.: Addl 2949/Addl CP/VC dated 10/5/12

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A		
	• Gate width	N/A		
	• Width of internal road	N/A		
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	one	one	MR
	• Upper floors	one	one	MR
	• Basements	N/A	N/A	N/A MR
	b. Width of staircases			
	• Upper floors	0.9m	1.15m	MR
	• Basements	N/A		
	c. Protection of exits			
	• Fire check door	N/A		
	• Pressurization	N/A		
	d. No of continuous staircase to terrace	one	one	MR

	e. Width Of Corridor	N/A		
	f. Door Size	N/A		
3.	Compartmentation			
	• Fire check door	N/A		
	• Sealing of electrical shafts	N/A		
	• Fire Rating of shaft door	N/A		
	• Water Curtain	N/A		
	• Fire Dampers	N/A		
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	
	• Upper floors	12 a/c per hour	N/A	
5.	Fire Extinguishers			
	• Total numbers	6	SIX	MR
	• Types	ISI marked	WT, CO2	MR
	• IS marking		YS	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	N/A		
	• Length of hose reel hose	N/A		
	• Nozzle diameter	N/A		
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A		
	• Location of Main Panel	N/A		
	• Location of Repeater Panel	N/A		
	• Alternate source of power	N/A		
	• Hooters' Location	N/A		
8.	MOEFA	N/A		
9.	Public Address System <i>Intol</i>	YS	YS	MR
10.	Automatic Sprinkler System			
	• Basements	N/A		
	• Upper Floor	N/A		
	• Sprinkler above false ceiling	N/A		
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A		

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 	N/A		
12.	Yard Hydrants	N/A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A		
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> • Discharge of main pump 	N/A		
	<ul style="list-style-type: none"> ➤ Head of main pump 	N/A		
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A		
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	N/A		
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A		
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A		
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A		
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual stopping 	N/A		
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A		
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	N/A		
	<ul style="list-style-type: none"> ➤ Head of the pump 	N/A		
	<ul style="list-style-type: none"> ➤ Power supply 	N/A		
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	N/A		
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	N/A		
	<ul style="list-style-type: none"> ➤ Draw of connection 	N/A		
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A		
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A		
	<ul style="list-style-type: none"> • Overhead Tank capacity 	N/A		
15	Exit Signage	yes	yes	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	N/A		
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	N/A		
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	N/A		

	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch ➤ Lift Signage 	N/A		
17.	Standby power supply	N/A		
18.	Refuge Area	Y9	Y9	MR
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	N/A		
19.	Fire control room	N/A		
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 	N/A		
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name ATULGAR

Designation DCFO/2

Signature of the Inspecting Officer

Name J. S. Yadav

Designation A.D.O (C.D)