


FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2012/2902 Dated: 08/08/2012

FIRE SAFETY CERTIFICATE

Certified that the **St. John's Public School** located at **P.O. Khera Khurd, Delhi-110082**. is comprised of Ground + One upper floor, total area 9565.21 sqm. & covered area 1273 sqm, was granted NOC by this department vide **letter No. F6/DFS/MS/2005/1539** dated 20/07/2005, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 20/07/2012 in the presence of **Sh. Bro. Alphonse (Manager)** and that the building / premises is fit for occupancy of **Group Class B (Educational)** with effect from **08 / 08 / 12** for a period of three years, subject to conditions mentioned over leaf.

Issued on 08/08/12 at New Delhi by



Chief Fire Officer
Delhi Fire Service

ou

Copy to:

1. St. John's Public School located at P.O. Khera Khurd, Delhi-110082
2. The Director of Education, Old Secretariat, Delhi

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

May kindly peruse letter no. nil dated 29/06/2012 received from Sh.Bro. Alphonse (Manager) **St. John's Public School** regarding issue of NOC form fire and safety point of view. In r/o **St. John's Public School located at P.O. Khera Khurd, Delhi-110082** The premises was inspected by the undersigned on dated 20.07.12 & observed that the school building is comprised of ground plus one upper floors only, total area 9565.21 sqm.& covered area 1273 sqm. However following fire safety measures are put up on the prescribe Performa

1. Name & address of the building : **St. John's Public School located at P.O. Khera Khurd, Delhi-110082.**
2. Type of Occupancy : Class -B (Educational)
3. Type of Case : renewal
4. Details of previous NOC : *N.O. - f6/ms/DFS/2005/1539 dated -20/7/2005.*
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 20/07/2012
7. Name of the Inspecting Officers : A.D.O. Rajmal Khokar
8. Name and designation of officers
From the building side : Sh.Bro. Alphonse (Manager)
9. Year of Construction :
10. Applicant's letter No. : nil dated 29/06/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

Noc already issued on dt 20.7.05 vide letter No F6/MS/DFS/2005/1539

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Required	Provided	M/R
	• Road width	06 mtrs	12 mtr ✓	M/R
	• Gate width	4.5 mtrs	5 mtr ✓	M/R
	• Width of internal road	3 mtrs.	6 mtrs. ✓	M.R.
2.	Number, Width, Type & Arrangement of Exits			

	a. Number of staircases	2	Provided ✓	M.R.
	• Upper Floors	Two	Provided ✓	M/R
	• Basement	N.A.	N.A.	Not applicable
	b. Width of staircases			
	• Upper Floors	1.5 mtr each	Provided ✓	M/R
	• Basement	N.A.	N.A.	Not applicable
	c. Protection of exits			
	• Fire check door	Not Required	N.R.	M.R.
	• Pressurization	N/R	N/R	Not applicable
	d. No. of continuous staircases to terrace	two	provided	M/R
	e. Width of Corridor	2 mtrs.	2 mtrs.	
	f. Door size	1.5 mtr	provided	M.R.
3.	Compartmentation.			
	• Fire check door	N/R	N/R	Not applicable
	• Sealing of electrical shafts	N/R	N/R	Not applicable
	• Fire Rating of shaft door	N/R	N/R	Not applicable
	• Water Curtain	N/R	N/R	Not applicable
	• Fire Dampers	N/R	N/R	Not applicable
4.	Smoke Management System.			
	• Basements	N.A.	N.A.	Not applicable
	• Upper floors	N/R	N/R	Not applicable
5.	Fire Extinguishers	Required	Provided	MR

	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>6 nos.</p> <p>ISI marked ABC type</p> <p>Yes</p>	<p>provided</p> <p>provided</p> <p>provided</p>	<p>M/R</p> <p>M/R</p> <p>M/R</p>
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>N.R.</p> <p>30 m N.R.</p> <p>5 mm N. required</p>	<p>provided</p> <p>provided</p> <p>Provided</p>	<p>M/R</p> <p>M/R</p> <p>M/R</p>
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	<p>N/R</p> <p>N/R</p> <p>N/R</p> <p>N/R</p> <p>N/R</p>	<p>N/R</p> <p>N/R</p> <p>N/R</p> <p>N/R</p> <p>N/R</p>	<p>Not applicable</p> <p>Not applicable</p> <p>Not applicable</p> <p>Not applicable</p> <p>Not applicable</p>
8.	MOEFA	N.A.	N.A.	N.A
9.	Public Address System.	Required	Provided	M/R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>N.R.</p> <p>N/R</p> <p>N/R</p>	<p>N.R.</p> <p>N/R</p> <p>N/R</p>	<p>Not applicable</p> <p>Not applicable</p> <p>Not applicable</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N.R.	N.A..	N.A.

	<ul style="list-style-type: none"> Number of hydrants per floor 	N.R.	Provided	M/R
	<ul style="list-style-type: none"> Hose Box 	N.R.	Provided	M/R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/R	N.A.	N.A..
	<ul style="list-style-type: none"> Hose Box 	N/R	N.A.	N.A.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	Not applicable
	➤ Head of Main pump	N/R	N/R	Not applicable
	➤ Number of main pumps	N/R	N/R	Not applicable
	➤ Jockey Pump out put	N/R	N/R	N.A.
	➤ Jockey pump head	N/R	N.A.	N.A.
	➤ Standby pump out put	N/R	N/R	Not applicable
	➤ Standby pump Head	N/R	N/R	Not applicable
	➤ Auto Starting/Manual stopping	N/R	N/R	Not applicable
	➤ Pump Hose Access	N/R	N/R	Not applicable
	Terrace level			
	➤ Discharge of pump	N/R	N/R	N.A.
	➤ Head of the pump	N/R	N/R	N.A.
	➤ Power supply	N/R	N/R	N.A.
	➤ Auto Starting of pump	N/R	N/R	N.A.

	➤ Auto Starting of pump	N/R	N/R	N.A.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N/R	N/R	Not applicable
	➤ Fire service inlet	N/R	N/R	Not applicable
	➤ Access to tank	N/R	N/R	Not applicable
	➤ Overhead Tank Capacity	N/R	N/R	N.A.
15	Exit Signage.	N.A.	N.A.	N.A
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	Not applicable
	• Pressurization of Lift lobby	N/A	N/A	Not applicable
	• Communication In lift Car	N/A	N/A	Not applicable
	• Fireman's Grounding Switch	N/A	N/A	Not applicable
	• Lift Signage	N/A	N/A	Not applicable
17.	Standby power supply			
18.	Refuge Area			
	➤ Total Area	N/R	N/R	Not applicable
	➤ Location	N/R	N/R	Not applicable
19.	Fire Control Room	N.A	N.A	NA

	➤ Detector System Panel	N/R	N/R	Not applicable
	➤ Flow Switch Panel	N/R	N/R	Not applicable
	➤ PA system Panel	N/R	N/R	Not applicable
	➤ Batter backup	N/R	N/R	Not applicable
	➤ Building Floor plans	N/R	N/R	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	Not applicable

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Rajmal Khokher

Name

Designation

Asstt. Div. officer

Designation