

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 2860

Dated: 06/08/12

FIRE SAFETY CERTIFICATE

Certified that the Bright Guest House located at M-85, Connaught Palace, New Delhi comprised of ground floor (Commercial other property), 1st floor (9 guest rooms, Reception + 01 office) and 2nd floor (other property) Total 09 guest rooms was granted NOC by this department vide letter No. F6/MS/DFS/GH/2009/182 dated 21-01-2009. The premises was re-inspected by the officer concerned of this department on 23-07-2012 in the presence of Sh. Tarun Aggarwal and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 09 guest rooms with effect from .06./08/.. 2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued .06./08./12 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. Shri Tarun Aggarwal M/s Bright Guest House, M-85, Connaught Palace, New Delhi-110001

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Bright Guest House, M-85, Connaught Palace, New Delhi 110001
2. Type of Occupancy : Lodging House.
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F6/MS/OPS/GH/2009/182 Dated: 21-01-2009
5. Fire Safety directives letter No : NA
6. Date of inspection : 23-07-2012
7. Name of the Inspecting Officers : Sh. D.S. Yadav (A.D.O)
8. Name and designation of officers from the building side : Sh. Tarun Aggarwal (owner)
9. Year of Construction : Starting Year: 1987
10. Applicant's letter No. : NIL Dated 12-07-12

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR Old Case. |
|--------|---|-----------------|------------------|--------------------------------|
| 1 | <u>Access to building</u> | | | |
| | • Road width | <u>18mtrs</u> | <u>18mtrs</u> | <u>M. R</u> |
| | • Gate width | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| | • Width of internal road | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| 2 | <u>Number, Width, Type & Arrangement of Exits</u> | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | <u>01</u> | <u>01</u> | <u>MR</u> |
| | • Basements | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| | b. Width of staircases | | | |
| | • Upper Floors | <u>120 cms</u> | <u>120 cms</u> | <u>NA</u> |
| | • Basements | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| | c. Protection of exits | | | |
| | • Fire check door | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| | • Pressurization | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| | e. No. of continuous staircases to terrace | <u>01</u> | <u>01</u> | <u>MR</u> |
| | g. Width of Corridor | <u>NA</u> | <u>NA</u> | <u>NA</u> |
| | h. Door Size | <u>NA</u> | <u>NA</u> | <u>NA</u> |

Contd.

old case

| | | I | I | P |
|----|--|-----------------|-------------------------------------|----|
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | / | / |
| | • Sealing of electrical shafts | NA | | |
| | • Fire Rating of shaft door | NA | | |
| | • Water Curtain | NA | | |
| | • Fire Dampers | NA | | |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | NA | NA |
| | • Upper floors | 12 a/c per hour | Natural Ventilation | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 04 | 04 | MR |
| | • Types | | Water CO ₂ A.B.C Type | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 01 (F.F) | 01 | MR |
| | • Length of hose reel hose | 30 m | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |

| | | | | |
|----|---|----------|-------------------------------|----|
| | <ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants • Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terra e level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | | NA | |
| | | 450 LPM | 450 LPM. | MR |
| | | 30 Mtrs. | 30 Mtrs. | MR |
| | | Electric | Electric | MR |
| | | — | Switch Provided at reception. | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection | NA | NA | NA |
| | | NA | NA | NA |

Bright Guest House, M-85, Connaught Palace, New Delhi

old case

| | | | | |
|----|--|------------|------------|----|
| | <ul style="list-style-type: none"> Fire service inlet | NA | NA | NA |
| | <ul style="list-style-type: none"> Access to tank | NA | NA | NA |
| | <ul style="list-style-type: none"> Overhead Tank capacity | 5000 Ltrs. | 5000 Ltrs. | MR |
| 15 | Exit Signage. | Yes | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft | | N.A | |
| | <ul style="list-style-type: none"> Pressurization of Lift lobby | | | |
| | <ul style="list-style-type: none"> Communication In lift Car | | | |
| | <ul style="list-style-type: none"> Fireman's Grounding Switch | | | |
| | <ul style="list-style-type: none"> Lift Signage | | | |
| 17 | Standby power supply | Yes | D.G. Set | MR |
| 18 | Refuge Area. | | | |
| | <ul style="list-style-type: none"> Total Area | NA | NA | NA |
| | <ul style="list-style-type: none"> Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> Detector System Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Flow Switch Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> PA System Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Batter backup | NA | NA | NA |
| | <ul style="list-style-type: none"> Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue short coming as noted at serial numbers.....

contd:-


Bright Guest House, M-85, Connaught Palace, New Delhi.

(5)


Signature of the Inspecting Officer

Name

Designation

D.O. (Central) 

CPD/HB 
1/8


23-07-12
Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional
Officer (Central)