

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F.6/DFS/MS/EH/2012/ 2962

Dated: 14/08/12

FIRE SAFETY CERTIFICATE

Certified that the **Restaurant Drool Kitchen (A unit of 4RS Hospitality Pvt. Ltd.)** at ground floor of Metro Commercial Space, Metro Station, Sec-10, Dwarka, New Delhi-110075. The restaurant running at ground floor only owned/ occupied by M/s 4RS Hospitality Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 06.08.2012 in the presence of Sh. Ravinder Dhankhar and that the building / premises is fit for occupancy class Group D assembly building Sub- Division D-6 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....14/08/12..... at New Delhi

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Deputy Health Officer,
Health Department, Najafgarh Zone,
M.C.D, New Delhi-110043.
(Ref. No. DHO/NGZ/2008/678 dated 24.07.12)
2. The Director
M/s 4RS Hospitality Pvt. Ltd.
Drool Kitchen Restaurant
Sec-10 Metro Station, Dwarka, New Delhi-75.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Ground Floor Only.

INSPECTION REPORT A Unit of YRS Hospitality Pvt. Ltd.

1. Name & address of the building : Dyool Kitchen, Metro Station Sec-16, Dewarka, Noida
2. Type of Occupancy : Group D, Sub Div D-6
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Date
5. Fire Safety directives letter No : N/A
6. Date of inspection : 06.08.2012
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O P.S. Dahiya
8. Name and designation of officers : Sh. Ravinder Dhankhar
From the building side
9. Year of Construction : 2011-12
10. Applicant's letter No. : DHO/NG2/2008/678 dated 24.07.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	12 mtr	MR
	• Gate width	-	180 cm	MR
	• Width of internal road/Side Road	-	06 mtr	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	-	-	Ground Floor
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	-	-	Ground Floor
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace	-	-	Ground Floor only.
	e. Width of Corridor	-	-	-
	f. Door Size	-	200 cm	MR
		-	133 cm x 205 cm	MR
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	N/A	-	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		-	G.F Only.

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	08 Nos	Provided	MR
	• Types	A.B.C	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	Provided Heat/Smoke	MR
	• Location of Main Panel	-	At Reception	MR
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G Set/125kVA	-
	• Hooters' Location	-	-	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	Ground Floor	Provided	MR
	• Sprinkler above false ceiling	MIA	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	Two	MR
	• Hose Box	-	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	1800 LPM	MR
	➤ Head of Main pump	-	70 M	MR
	➤ Number of main pumps	-	One	MR
	➤ Jockey Pump out put	-	180 LPM	MR
	➤ Jockey pump head	-	30 M	MR
	➤ Standby Pump out put	-	1800 LPM	MR
	➤ Standby Pump Head	-	70 M	MR
	➤ Auto Starting/Manual stopping	-	Both	MR

Metro Station Sec-10,
Dwarka, New Delhi - 110075.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		-	Pump Provided at Ground level	MR
		-	- do -	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-	50000 Ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	- do -	- do -	MR
	➤ Access to tank	- do -	- do -	MR
	• Overhead Tank capacity	-	U.G Tank of 50000 Ltr Cap. Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-	-	No Lift
	• Pressurization of Lift lobby	-	-	- do -
	• Communication In lift Car	-	-	- do -
	• Fireman's Grounding Switch	-	-	- do -
	• Lift Signage	-	-	- do -
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	-	-
	➤ Location	N/A	-	-
19.	Fire Control Room			
	• Detector System Panel	N/A	-	-
	• Flow Switch Panel	N/A	-	-
	• PA System Panel	N/A	-	-
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The restaurant running at Ground floor only under metro Railway Line at Metro Commercial Space, Metro Station Sec-10, Dwarka, New Delhi - 110075. The Restaurant having two exits and properly ventilated. The kitchen facilitated with exhaust fans. The sprinkler system, hoses & yard hydrants connected with the fire safety arrangements of Metro Station Building. The seating capacity of above restaurant is 74 only.



Signature of Inspecting Officer

Name H.L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P.S. Sahiya

Designation Asstt. Divisional Officer.