

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/School/2012/ 2974

Dated 14/08/12

FIRE SAFETY CERTIFICATE

Certified that the – **Sarvodaya Bal Vidyalaya, at A-Block, Vikas Puri, New Delhi-110018** Comprised of - ground floor plus three upper floors, owned/occupied by Director of Education, Govt. of N.C.T of Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules-2010 and verified by the officer concerned of fire Service on .25.07.12 in the presence of Sh. Anil Kumar, Principal and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on14/08/12.....at New Delhi.


Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal,
Sarvodaya Bal Vidyalaya,
A-Block, Vikas Puri,
New Delhi-110018.
2. The Director of Education
Govt. of NCT of Delhi
Old Secretariat, Delhi.
3. Divisional Officer (South West) SRD.

Note * :- For general fire safety directives please see overleaf

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the responsibility of the management.
3. The staff should be trained available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Bal Vidyalaya, A-Block, Vikas Puram
 2. Type of Occupancy : Education N.D. 18.
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. NIL Dated: _____
 5. Fire Safety directives letter No : FC/OPS/20011/SHMD/3427 dt 9/12/11
 6. Date of inspection : 25/7/12
 7. Name of the Inspecting Officers : D.O. H. CANESA
 8. Name and designation of officers from the building side : Sh Anil Kumar Principal
 9. Year of Construction : _____
 10. Applicant's letter No. : SBR/ABUK/VP/215 dt 11/6/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	19 mtr	MR
	• Gate width		3.40 mtr	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	b. Width of staircases	R	121421 Cms	MR
	• Upper Floors	—	—	—
	• Basements	MR	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	2 Nos	MR
	g. Width of Corridor	R	2.40 mtr	MR
	h. Door Size	R	210 X 110 Cms	MR

3	Compartmentation.				
	• Fire check door	NR			
	• Sealing of electrical shafts				
	• Fire Rating of shaft door				
	• Water Curtain				
	• Fire Dampers				
4	Smoke Management System.	HK			
	• Basements	30 a/c per hour			
	• Upper floors	12 a/c per hour			
5	Fire Extinguishers	R	P	MR	
	• Total numbers		16 Nos	MR	
	• Types		ABC type		
	• IS marking	ISI marked	Yes		
6	First-Aid Hose Reels.	R	P	MR	
	• Total numbers on each floor		8 Nos		
	• Length of hose reel hose	30 m	30mtr		
	• Nozzle diameter	5 mm	P		
7	Automatic fire detection and alarming system.	NR			
	• Type of detectors				
	• Location of Main Panel				
	• Location of Repeater Panel				
	• Alternate source of power				
	• Hooters' Location				
8	MOEFA	NR			
9	Public Address System.	NR			
10	Automatic Sprinkler System.	NR			
	• Basement	HK			

7	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 Lts	10,000	MR
15	Exit Signage.	MR	—	—
16	Provision of Lifts.	MR	—	—
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
	—	—	—	—
17	Standby power supply	MR	—	—
18	Refuge Area.	—	—	—
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	MR	—	—
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	MR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... MR —

5

Handwritten signature

Signature of the Inspecting Officer

Name

H. L. ANEJA

Designation

Dir. Officer

Signature of the Inspecting Officer

Name

Designation

Handwritten signature