

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 2978

Dated: 14/08/12

**FIRE SAFETY CERTIFICATE**

Certified that M/s Siraj Guest House located at 4026, Gali Khan Khana, Urdu Bazar, Jama Masjid, Delhi comprised of ground floor (Commercial use), first floor (09 guest rooms + reception) and second floor (08 guest rooms) as granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/838 dated 24-03-2009. The premises was re-inspected by the officer concerned of this department on 01-08-2012 in the presence of Haji Siraj Ahmed, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 14/08/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 14/08/12 at New Delhi by.

  
Chief Fire Officer  
Delhi fire service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi
2. The Manager, M/s Siraj Guest House, 4026, Gali Khan Khana, Urdu Bazar, Jama Masjid, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

88/44/01/09/18/AM

http://scmr.net.in/newlook/DP20120714AdminCard.asp

2 of 4  
http://scmr.net.in/newlook/DP20120714AdminCard.asp

Old case.

**INSPECTION REPORT**

1. Name & address of the building : Siraj Guest House, 4021-26, Gali Khan Khana  
2. Type of Occupancy : Lodging House / ~~Eating House~~ / Club Jama Masjid, Delhi  
3. Type of Case : Renewal / ~~New case~~  
4. Details of previous NOC : Letter No. FB/DFE/MS/GH/09/838 Dated: 24/3/09  
5. Fire Safety directives letter No : -  
6. Date of inspection : 1/8/2012  
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)  
8. Name and designation of officers from the building side : Haji Siraj Ahmed, Manager  
9. Year of Construction : 1976  
10. Applicant's letter No. : nil date 26/7/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Spf area</u>	<u>02mt Gali f 20mt away from main road</u>	<u>MR being old case.</u>
	• Gate width	<u>-</u>	<u>Directly accessible from main road</u>	<u>MR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>01</u>	<u>01</u>	<u>MR being old case.</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>-</u>
	b. Width of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>0.80mt</u>	<u>0.90mt</u>	<u>MR</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	• Pressurization	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	e. No. of continuous staircases to terrace	<u>01</u>	<u>01</u>	<u>MR</u>
	g. Width of Corridor	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	h. Door Size	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
		<u>N/A</u>	<u>N/A</u>	<u>-----</u>
3	<b>Compartmentation.</b>	<b>Not required</b>	<u>N/A</u>	<u>-</u>

*[Handwritten signature]*



	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers 05</li> <li>• Types water CO<sub>2</sub>, CO<sub>2</sub>, ABC</li> <li>• IS marking</li> </ul>	water CO <sub>2</sub> -2 CO <sub>2</sub> -2 ISI marked	provided provided provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	2nd floor 30 m 5 mm	provided provided provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
8	<b>MOEFA</b>	NA	NA	—
9	<b>Public Address System.</b>	NA	NA	—
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	—
		N/A	N/A	-----
		N/A	N/A	-----
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	N/A	N/A	-----

g

	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	-----
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	-----
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	---
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	---	---	---
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	225 LPM	225 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	30 mt	30 mt	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	---	starting switch provided near reception	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	2500 Lts	2500 Lh	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	N/A	-----

*J*

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	N/A	N/A	-----
17	<b>Standby power supply</b>	<i>Required</i>	<i>15 KVA</i>	<i>MR</i>
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	N/A	N/A	-----
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	<i>Required</i>	<i>One ABC type Fire Ext. provided near elect. panel.</i>	<i>MR</i>

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
Name  
Designation

  
Signature of the Inspecting Officer  
Name (M.K. CHATTOPADHYAY)  
Designation :- Assistant Divisional Officer

*DCFO (COP)*  
*[Signature]*  
*8/10/12*