

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/EH/2012/ 2983

Dated : 16/8/12

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of Gem Restaurant, at ground floor and 1st floor located at 1050, Main Bazar, Pahar Gnaj, New Delhi-110055 comprised of ground plus three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/2951 dated 06-10-2009. The premises was re-inspected by the officer concerned of this department on 31-07-2012 in the presence of Mr. Amardeep Singh (owner) and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for Class D (Assembly) occupancy with effect from ...16/08/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued ...16/8/12 at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

dc
16-08-12
A.D.O (C.D)

Copy to :-

1. M/s Gem Restaurant, 1050, Main Bazar, Pahar Ganj, New Delhi-110055
2. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi - 110049.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

The Gem Restaurant, 1050, main Bazar,

1. Name & address of the building : Pahar Ganj, New Delhi-110055
2. Type of Occupancy : Restaurant (Assembly)
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NCC : Letter No. FG/DFS/M.S/E.H/2009/2951 Dated: 16-10-2009
5. Fire Safety directives letter No : - N.A -
6. Date of inspection : 31-07-2012
7. Name of the Inspecting Officers : Dharm veer singh yadav (A.D.O)
8. Name and designation of officers from the building side : Shri Amardeep singh
9. Year of Construction : 2005 starting year.
10. Applicant's letter No. : NIL dated 13-07-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR <i>old case</i>
1	Access to building			
	• Road width	<u>4.5 mtrs</u>	<u>more than 06 mtrs</u>	<u>M.R</u>
	• Gate width	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	• Width of internal road	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>01</u>	<u>01</u>	<u>M.R</u>
	• Basements	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	b. Width of staircases			
	• Upper Floors <i>(Two Exits)</i>	<u>N.A</u>	<u>90cms to 110cms</u>	<u>M.R</u>
	• Basements	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	c. Protection of exits			
	• Fire check door	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	• Pressurization	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	e. No. of continuous staircases to terrace	<u>01</u>	<u>01</u>	<u>M.R</u>
	g. Width of Corridor	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	h. Door Size	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>

contd:-

The Gem Restaurant, 1050, main Bazar

3	Compartmentation.			
	• Fire check door		N.A	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour	N.A	M.R
	• Upper floors	12 a/c per hour	Exhaust Fans	M.R
5	Fire Extinguishers			
	• Total numbers	08	08	M.R
	• Types	—	CO2 type & ABC Type	M.R
	• IS marking	ISI marked	yes	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	M.R
	• Length of hose reel hose	30 m	yes	M.R
	• Nozzle diameter	5 mm	yes	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors		N.A	
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA	yes	Provided	M.R
9	Public Address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	• Basement	N.A	N.A	N.A

contd:-

The Gem Restaurant, 1050, Main Bazar,
Pahar Ganj, New Delhi-110055

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	yes	Provided	M.R
		N.A	N.A	N.A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose box 	100 M.M.	100 M.M.	M.R
		at ground floor (one)	At ground floor (one)	M.R
		yes (one)	yes one	M.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.A	N.A	N.A
		N.A	N.A	N.A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level Discharge of pump Head of the pumps Power Supply Auto Starting of pump 		N.A	
		Main Pump 450 LPM	450 LPM	M.R
		Jockey Pump 180 LPM	180 LPM	M.R
		each 40 mtrs	each 40 mtrs	M.R
		Electricity	Electricity	M.R
		yes	Provided	M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	N.A	N.A	N.A
		N.A	N.A	N.A

contd :-

The Gem Restaurant, 1050,
Main Bazar, Paharganj, New Delhi
110055

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p>yes</p> <p>yes</p> <p>5000 litres</p>	<p>provided</p> <p>provided</p> <p>5000 litres</p>	<p>M-R</p> <p>M-R</p> <p>M-R</p>
15	Exit Signage.	yes	provided	M-R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		<p>\</p> <p>N.A</p> <p>\</p>	
17	Standby power supply	yes	D.G. set	M-R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	<p>N.A</p> <p>N.A</p>	<p>N.A</p> <p>N.A</p>	<p>N.A</p> <p>N.A</p>
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		<p>\</p> <p>N.A</p> <p>\</p>	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcoming as noted at serial numbers.....

contd:-

The Gem Restaurant, 1050 main Bazar,
Pahar Ganj, New Delhi-110055

Signature of the Inspecting Officer

Name

Designation

DCFO-II
19/8/12

D. Singh
31-7-12

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional
officer (central)