


FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FG/DFS/MS/Indll/2012/2991 Dated: 17/08/2012

**FIRE SAFETY CERTIFICATE**

Certified that the **Kapur Rubber Industries** located at A-4, Mangol Puri Industrial Area, Phase-II, New Delhi-110034, comprised of basement+ground+one upper floor, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **18-07-2012** in the presence of **Mr. Ashwani Kapur** of the factory and that the premises is fit for **Class-G (G1) Industrial** occupancy with effect from .....17/08/12..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....17/08/12.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to:  
**Mr. Ashwani Kapur**  
Kapur Rubber Industries  
A-4, Mangol Puri Industrial Area,  
Phase-II, New Delhi-110034

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. nil dated nil received from the Partner for Kapur Rubber Industries., regarding of NOC in r/o **Kapur Rubber Industries** located at A-4, Mangol Puri Industrial Area, Phase-II, New Delhi-110034. Premises was inspected & observed that the building comprised of <sup>Basement</sup> ground floor, ~~Mezz.~~ floor & first floor only. Fire safety arrangements are put up on the prescribed Performa :-

1. Name & address of the building : Kapur Rubber Industries located at A-4, Mangol Puri Industrial Area, Phase-II, New Delhi-110034.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : F.6/DFS/MS/BP/832 dated 27.04.1998
6. Date of inspection : 18-07-2012
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers  
From the building side : Mr. Ashwani Kapur
9. Year of Construction :
10. Applicant's letter No. : Nil dated nil

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12 mtr	Provided 24 mtr	M.R.
	• Gate width	5 mtr	Provided	M.R.
	• Width of internal road	As per sanction plan	Provided	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	2	Provided	M.R.
	• Upper Floors	2	Provided	M.R.

	<ul style="list-style-type: none"> <li>Basement</li> </ul>	2	Provided	M.R. ✓
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	1.25 mtr as per sanction plan	Provided ✓	M.R. ✓
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	1.25 mtr as per sanction plan	Provided ✓	M.R. ✓
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N.R.	N.R.	N.R. ✓
	d. No. of continuous staircases to terrace	2	Provided	M.R. ✓
	e. Width of Corridor	Halls only	Halls only	M.R. ✓
	f. Door size	1.25 mtr	Provided	M.R. ✓
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N.R.	N.R.	N.R. ✓
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N.R.	N.R.	N.R. ✓
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N.R.	N.R.	N.R. ✓
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	required	Exhaust fans are provided	M.R. ✓
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	M.R. ✓
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	15	18	M.R. ✓
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC type	provided	M.R. ✓



	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	ISI marked required	provided	M.R.
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1	Provided	M.R.
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required 1	provided	M.R.
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm required	provided	M.R.
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.R.	N.R.	N.A.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.R.	N.R.	N.A.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.R.	N.R.	N.A.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.R.	N.R.	N.A.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N.R.	N.R.	N.A.
<b>8.</b>	<b>MOEFA</b>			
		N.R.	N.R.	M.R.
<b>9.</b>	<b>Public Address System.</b>			
		N.R.	N.R.	N.A.
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	No false ceiling	N.R.	N.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 m Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	1	Provided	M.R.

	• Hose Box	1	Provided	M.R. ✓
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	Not applicable ✓
	• Hose Box	N.R.	N.R.	Not applicable ✓
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.R.	N.R.	N.R ✓
	➤ Head of Main pump	N.R.	N.R.	N.R ✓
	➤ Number of main pumps	N.R.	N.R.	N.R ✓
	➤ Jockey Pump out put	N.R.	N.R.	N.R ✓
	➤ Jockey pump head	N.R.	N.R.	N.R ✓
	➤ Standby pump out put	N.R.	N.R.	N.R ✓
	➤ Standby pump Head	N.R.	N.R.	N.R ✓
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R ✓
	➤ Pump Hose Access	N.R.	N.R.	N.R ✓
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	Provided	M.R ✓
	➤ Head of the pump	<del>60 mtr</del> 30 mtr dn ✓	provided	M.R ✓
	➤ Power supply	Required	provided	M.R ✓
	➤ Auto Starting of pump	Manual	Provided	M.R ✓

<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	10,000 ltr	Provided	M.R. ✓
	➤ Draw -off connection	Required	Provided	M.R. ✓
	➤ Fire service inlet	Required	Provided	M.R. ✓
	➤ Access to tank	Required	Provided	M.R. ✓
	➤ Overhead Tank Capacity	12,500 ltr	provided	M.R. ✓
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R. ✓
<b>16.</b>	<b>Provision of Lifts</b>	<b>N.R.</b>	<b>N.R.</b>	<b>N.R.</b>
	• Pressurization of Lift Shaft	N.A.	N.R.	N.R. ✓
	• Pressurization of Lift lobby	N.A.	N.R.	N.R. ✓
	• Communication In lift Car	N.A.	N.R.	N.R. ✓
	• Fireman's Grounding Switch	N.A.	N.R.	N.R. ✓
	• Lift Signage	N.A.	N.R.	N.R. ✓
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R. ✓
<b>18.</b>	<b>Refuge Area</b>	N.R.	N.R.	N.A. ✓
	➤ Total Area	N.R.	N.R.	N.A. ✓
	➤ Location	N.R.	N.R.	N.A. ✓
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.R.	N.R.	Not applicable ✓
	➤ Flow Switch Panel	N.R.	N.R.	Not applicable ✓
	➤ PA system Panel	N.R.	N.R.	Not applicable. ✓

	➤ Batter backup	N.R.	N.R.	Not applicable. ✓
	➤ Building Floor plans	N.R.	N.R.	Not applicable ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

*Sonil chawdhary*

Name

Designation

*D.O. (west)*

Designation

*Please create on*