

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 3009

Dated: 17/8/12

FIRE SAFETY CERTIFICATE

Certified that the Namaskar Guest House, 917, Gali Chandiwali, Main Bazar, Pahar Ganj, New Delhi-110055 comprised of ground floor (07 guest rooms + reception) and 1st floor to 3rd floor (09 Guest rooms at each floor) Total 34 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/2055 dated 09-07-2009. The premises was re-inspected by the officer concerned of this department on 30-07-2012 in the presence of Sh. Rajinder Kumar (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 34 guest rooms with effect from 17/8/12 2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 17/8/12 at New Delhi by.

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049.
2. M/s Namaskar Guest House, 917, Gali Chandiwali, Main Bazar, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Namashkar guest house, 917, Gali Chandiwali, main Bazar, Pataar Gant, New Delhi-110055
2. Type of Occupancy : Lodging House -
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F6/DFS/MS/GH/2009 Dated: 09-07-09
5. Fire Safety directives letter No : NIL 2005.
6. Date of inspection : 30-07-2012
7. Name of the Inspecting Officers : Dharm vir singh yadav
8. Name and designation of officers from the building side : Shri Rajinder Kumar.
9. Year of Construction : starting year 2001
10. Applicant's letter No. : NIL dated 13-07-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			old case PSS Area
	• Road width	N.A	08 Feet wide Gali	M.R
	• Gate width	N.A	N.A	N.A
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	M.R
	• Basements	N.A	N.A	N.A
	b. Width of staircases			
	• Upper Floors	80 Cms.	110 Cms	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	NA	NA	NA
	h. Door Size	NA	NA	NA

contd:-

3	Compartmentation.			
	• Fire check door	NA	-	-
	• Sealing of electrical shafts	NA	-	-
	• Fire Rating of shaft door	NA	-	-
	• Water Curtain	NA	-	-
	• Fire Dampers	NA	-	-
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	12	12	MR
	• Types	-	Water Co ₂ & A.B.C Type	MR
	• IS marking	ISI marked	provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	-	-
	• Location of Main Panel	NA	-	-
	• Location of Repeater Panel	NA	-	-
	• Alternate source of power	NA	-	-
	• Hooters' Location	NA	-	-
8	MOEFA	Yes	Provided	MR
9	Public Address System.	Yes	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	NA	—	—
11	Internal Hydrants	NA	—	—
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	—	—
12	Yard Hydrants.	NA	—	—
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	—	—
13	Pumping Arrangements.	NA	—	—
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		225 LPM	225 LPM	MR
		30 mtrs	30 mtrs.	MR
		Electric	Electric	MR
		—	Switch provided at G.P.	MR
14	Captive Water Storage for fire fighting.	NA	—	—
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	NA	—	—

Conda.:-

Namaskar Guest House, 917, Gali Chandiwali, Main Bazar, Pahar Ganj, New Delhi.

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	—	—
		NA	—	—
		2500 Ltrs.	2500 Ltrs.	MR
15	Exit Signage.	Yes	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	—	—
	• Pressurization of Lift lobby	NA	—	—
	• Communication In lift Car	NA	—	—
	• Fireman's Grounding Switch	NA	—	—
	• Lift Signage	NA	—	—
17	Standby power supply	Yes	D. G. Set	MR
18	Refuge Area.			
	➤ Total Area	NA	—	—
	➤ Location	NA	—	—
19	Fire Control Room			
	• Detector System Panel	NA	—	—
	• Flow Switch Panel	NA	—	—
	• PA System Panel	NA	—	—
	• Batter backup	NA	—	—
	• Building Floor Plans	NA	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Contd. :-

Namaskar Guest House, 917, Gali Chandiwali, Main Bazar
Pahar Ganj, New Delhi. (5)

Signature of the Inspecting Officer

Name

Designation

~~DCFO / [Signature]~~
11/8/12

Signature of the Inspecting Officer

Name D. S. Yadav

Designation A.D.O (C.D.)

[Signature]
20-7-12