

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 3032

Dated: 21/08/12


FIRE SAFETY CERTIFICATE

Certified that M/s The Sun Court Hotel Yatri located at 8-A/33, W.E.A., Karolbagh, New Delhi comprised of Basement (01 hall + 02 rooms for storage), ground floor (03 guest rooms + reception), first floor (07 guest rooms), second floor (07 guest rooms), third floor (07 guest rooms) and fourth floor (Pantry + 01 staff room) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/2622 dated 26-08-2009. The premises was re-inspected by the officer concerned of this department on 01-08-2012 in the presence of Mr. Raj Yadav, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 21/08/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 21/08/12 at New Delhi by.



**Chief Fire Officer
Delhi fire service**



Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, The Sun Court Hotel Yatri, 8-A/33, W.E.A., Karolbagh, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

Old case

INSPECTION REPORT

1. Name & address of the building : Sun Court Hotel, 8A/33, WEA, Karol Bagh, New Delhi.
2. Type of Occupancy : Lodging House / ~~Eating House~~ / Club.
3. Type of Case : Renewal / ~~New case~~
4. Details of previous NOC : Letter No. FE/DFs/MS/CH/09/2622 Dated: 26/8/2009
5. Fire Safety directives letter No : -
6. Date of inspection : 01/08/2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
8. Name and designation of officers from the building side : Mr. Raj yadav, Manager
9. Year of Construction : 1970 & 1998
10. Applicant's letter No. : 30088/ Addl. C-P/42(CH) deli 23/5/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06mt	18mt	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	NA	NA	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case.
	• Basements	01	01	MR being old case.
	b. Width of staircases	-	-	-
	• Upper Floors	1.25mt	1.32mt	MR being old case.
	• Basements	1.25mt	1.32mt	MR being old case.
	c. Protection of exits	-	-	-
	• Fire check door	NA	NA	-
	• Pressurization	NA	NA	-
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	NA	NA	-
	h. Door Size	NA	NA	-
3	Compartmentation.	Not required	NA	-

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan provided	MR
			N/A	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 08 • Types water CO₂, CO₂ • IS marking 	ISI marked	provided	MR
			provided	MR
			provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	provided	MR
			provided	MR
			provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
8	MOEFA	N/A	N/A	-
9	Public Address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	provided	MR
		N/A	N/A	-
		N/A	N/A	-
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	-

g

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	N/A	N/A	-
		N/A	N/A	-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	-
		N/A	N/A	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		450 LPM	provided	MR
		30mtr	provided	MR
		Required	provided	MR
		N/A	N/A	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		5000 ltr.	provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	-

J

	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	-
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	-
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	-
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	-
17	Standby power supply	Required	82 f 40 KVA	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	-
	➤ Location	NA	NA	-
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	-
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	-
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	-
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	-
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	provided one CO ₂ type fire ext. near elect. panels	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation :- Assistant Divisional Officer

DFO (CD) 