

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2012 / 21 / 3066

Dated 24/08/12

FIRE SAFETY CERTIFICATE

Certified that the M/s Dimsum Brothers, Restaurant located at K-185/1, Sarai Jullena New Friends Colony, New Delhi, comprised of Basement + Ground + 03 Upper Floors (but the restaurant is running on Ground Floor only) owned occupied by Dimsum Brothers, was inspected by the officers concerned of this department on 16.08.2012 in the presence of Mr. Ajay Saini (Manager) and found that the said restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group - D Assembly Building with effect from _____ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. .

Issued on at New Delhi by.


24/8
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer,
Health Department, Central Zone, Lajpat Nagar, New Delhi.
2. M/s Dimsum Brothers (Ground Floor) located at K-185/1, Sarai Jullena New Friends Colony, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be uses as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Ground floor only

INSPECTION REPORT

1. Name & address of the building : DIMSUM BROTHERS
: Premises No K-1851, Sarai Jullana
: New friends colony
2. Type of Occupancy : EATING HOUSE
3. Type of Case : NEW
4. Details of previous NOC : NIL Dt. NIL
5. Fire Safety Directives letter No : NIL
6. Date of Inspection : 16-8-12
7. Name of the Inspecting Officer : Rajen Madhira
8. Name and designation of the Officers from the building side : sh Ajay Saini - Manager
9. Year of Construction : - 09
10. Applicant's letter No. : NIL

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	30 mts	30 mts	MIR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits	NA (Ground floor)		
	• Number of Staircase			
	➤ Upper floors	NA	NA	NA
	➤ Basement	NA	NA	NA
	• Width of Staircase	NA		
	➤ Upper floors			
	➤ Basement			
	• Protection of Exits	NA		
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size / Width	2 NOS	2 mts each	MIR

3	Compartmentation			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper Floors	12 A/c Per hr	12 A/c Per hr	M/R
5	Fire Extinguishers			
	• Total Number	1 / 300 m ²	12 Nos	M/R
	• Types	ABC / CO2	8 ABC, 4 CO2	M/R
	• IS marking	ISI mark	Yes	M/R
6	First-Aid Hose Reels			
	• Total Number on each floor	1 / Per Floor	1	M/R
	• Length of hose reel hose	30 m	30 m	M/R
	• Nozzle diameter	5 mm	5 mm	M/R
7	Automatic Fire Detection and Alarming System	NA		
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooter's Location			
8	MOEFA	Required	Provided	M/R
9	Public Address System	NA		
10	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	M/R
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrant			
	• Size of riser/down comer	100 mm	100 mm	M/R
	• Number of hydrants per floor	1	1	M/R
	• Hose Box	1	1	M/R
12	Yard Hydrant			
	• Total Number of hydrants	1	1	M/R
	• Hose Box	1	1	M/R

13	Pumping Arrangements	NA		
	Ground Level			
	➤ Number of main pump	/	/	/
	➤ Discharge of main pump	/	/	/
	➤ Head of main pump	/	/	/
	➤ Jockey pump out put	/	/	/
	➤ Jockey pump Head	/	/	/
	➤ Standby pump out put	/	/	/
	➤ Standby Pump Head	/	/	/
	➤ Auto Starting/Manual stopping	/	/	/
	➤ Pump House Access	/	/	/
	Terrace level			
	➤ Discharge of pump	1 Main Pump 1 Jockey Pump	950 LPM 180 LPM	950 LPM 180 LPM
	➤ Head of the pump		25mts	25mts
	➤ Power Supply		120 KVA	120 KVA
	➤ Auto starting /Manual stopping		Auto	Auto
				MIR
				MIR
				MIR
				MIR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	10,000 Us	10,000 Us	MIR
	➤ Draw-off connection	Required	Provided	MIR
	➤ Fire service inlet	Required	Provided	MIR
	➤ Access to tank	Required	Provided	MIR
	• Overhead tank capacity	20,000 Us	20,000 Us	MIR
15	Exit Signage	Reported	Provided	MIR
16	Provision of Lifts	NA		
	• Pressurization of Lift Shaft	/	/	/
	• Pressurization of Lift lobby	/	/	/
	• Communication in lift Car	/	/	/
	• Fireman's Grounding Switch	/	/	/
	• Lift Signage	/	/	/
17	Standby Power Supply	120 KVA	120 KVA	MIR
18	Refuge Area	NA		
	• Total Area	/	/	/
	• Location	/	/	/
19	Fire Control Room	NA		
	• Detector System Panel	/	/	/
	• Flow Switch Panel	/	/	/
	• PA System Panel	/	/	/
	• Battery back up	/	/	/
	• Building Floor Plans	/	/	/

20	Special Fire Protection System for Protection of special risk, if any	4 ABC fire ext.	4 ABC fire ext	MIR
----	---	-----------------	----------------	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at~~ serial Number _____

DO (S) on leave

N. C. F. O. (S)



Signature of Inspecting Officer
 Name : RAJAN WADEHRA
 Designation: A. D. O. (M.Rd.)