

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO.F6/DFS/MS/EH/2012/ 3050

Dated: 22/08/12

FIRE SAFETY CERTIFICATE

Certified that the **M/s Dominos Pizza (A unit of Jubilant Foods Works ltd.)** restaurant located at first & Mezzanine floor of N-6&7, Connaught Circus, New Delhi comprised of ground and two upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi fire service on 06.08.2011 in the presence of Mr. Amiyon, Manager of the restaurant and that the building/premises is fit for occupancy **class Assembly (Restaurant)** with effect from 22/08/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/08/12 at New Delhi by.


**Chief Fire Officer
Delhi fire service**

Copy to: -

1. The Dy. Health Officer, MCD, Central Zone, Lajpat Nagar, New Delhi
2. The Manager, M/s Dominos Pizza (A unit of Jubilant Foods Works ltd.), N-6&7, Connaught Circus, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Dominos Pizza restaurant, N 7, Connaught Circus, New Delhi
2. Type of Occupancy : Lodging house Restaurant
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FG/DFS/MS/EH/2009/1459 Dated: 25/5/09
(Wompy Restaurant)
5. Fire Safety directives letter No : _____
6. Date of inspection : 06/08/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay
8. Name and designation of officers from the building side : Mr. Amrison, Manager
9. Year of Construction : _____
10. Applicant's letter No. : M04/D/1250/CSI (Lic) /SI-I dated 20/6/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06mt	20mt	MR
	• Gate width	—	Directly accessible from the main road	MR
	• Width of internal road	N/A	N/A	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02 (01 main) (01 through Dunkin's Donuts) Sealed	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.25mt	1.45mt, 1.05mt	MR
	• Basements	—	Sealed (not in use)	MR
	c. Protection of exits	—	—	—
	• Fire check door	—	Provided in Mez floor between two restaurant	MR
	• Pressurization	N/A	N/A	—
	e. No. of continuous staircases to terrace	01	01 (separate)	MR
	g. Width of Corridor	N/A	N/A	—
	h. Door Size	—	2.0 mt	MR
		—	—	—
3	Compartmentation.	—	—	—

Ground floor → Restaurant
 Mez. floor → Restaurant
 1st floor (separate entry) → Bank & Office.

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	FCD provided between two restaurant	MR
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	-
			Smoke venting provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 04 • Types ABC type • IS marking 	ISI marked	provided	MR
			provided	MR
			provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	provided	MR
			provided	MR
			provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	- Ground floor N/A Required Required	Smoke detector Ground floor N/A provided 64 KVA Each floor near	MR MR - MR MR
8	MOEFA	Required	provided	MR
9	Public Address System.	N/A	N/A	-
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A Required N/A	N/A provided N/A	- MR -
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	-

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 	N/A	N/A	-
		N/A	N/A	-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	-
		N/A	N/A	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		-	-	-
		4.50 LPM	provided	MR
		30 mt	provided	MR
		Required	provided	MR
		Required	starting switch provided near GF	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		5000 ltr	10,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	N/A	N/A	-
		N/A	N/A	-

J

	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	-
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	-
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	-
17	Standby power supply	Required	64 KVA	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	-
	➤ Location	NA	NA	-
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	-
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	-
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	-
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	-
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire extinguisher provided near elect panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~renew~~^{grant} Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name
Designation

Signature of the Inspecting Officer

Name M. K. CHATTOPADHYAY
Designation ADO (HO)