

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/EH/2012/ 3049

Dated: 22/08/12

FIRE SAFETY CERTIFICATE

Certified that the M/s Dunkin Donuts (A unit of Jubilant Foods Works ltd.) Restaurant located at first & Mezzanine floor of N-6, Connaught Circus, New Delhi comprised of ground and two upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi fire service on 06.08.2011 in the presence of Mr. Sumit, Manager of the restaurant and that the building/premises is fit for occupancy class **Assembly (Restaurant)** with effect from 22/08/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/08/12 at New Delhi by.


**Chief Fire Officer
Delhi fire service**

Copy to: -

1. The Dy. Health Officer, MCD, Central Zone, Lajpat Nagar, New Delhi
2. The Manager, M/s Dunkin Donuts (A unit of Jubilant Foods Works ltd.), N-6, Connaught Circus, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Dunkin Donuts, N-6, Connaught Circus, J&K
2. Type of Occupancy : Lodging house Restaurant
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FB/DFS/MS/EH/2009/1459 Dated: 25/5/2009
5. Fire Safety directives letter No : _____ (Wimply Restaurant)
6. Date of inspection : 06/08/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay
8. Name and designation of officers from the building side : Mr. Sumit, Manager
9. Year of Construction : Before 1947
10. Applicant's letter No. : Molt/D/1249/CS(Lic)/SI-I dated 20/6/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06mtr	20mtr	MR
	• Gate width	-	Directly accessible from the main road	MR
	• Width of internal road	N/A	N/A	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02 (01 main) (01 through Dominos)	MR
	• Basements	-	Sealed (Storage)	MR
	b. Width of staircases			
	• Upper Floors	1.25mt	1.05mt, 1.45mt	MR
	• Basements	-	Sealed (not in use)	-
	c. Protection of exits			
	• Fire check door	-	Fire check door provided at Neg Floor between fire	MR
	• Pressurization	N/A	N/A	-
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-
	h. Door Size	2.0 mt	2.0 mt	MR
		-	-	-
3	Compartmentation.	-	-	-

[Signature]

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>—</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>FCD provided between floors (Corridor & Quater) panels</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>MR</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>12 a/c per hour</p>	<p>N/A</p> <p>Exhaust Fan provided & Smoke venting</p>	<p>—</p> <p>MR</p>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 06 • Types ABC type • IS marking 	<p>ISI marked</p>	<p>provided</p> <p>provided</p> <p>provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<p><u>Meq. Floor</u></p> <p>30 m</p> <p>5 mm</p>	<p>provided</p> <p>provided</p> <p>provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	<p>Smoke</p> <p>GF</p> <p>—</p> <p>Required</p> <p>GF & Meq Floor</p>	<p>provided</p> <p>provided</p> <p>—</p> <p>GU KVA provided</p> <p>provided</p>	<p>MR</p> <p>MR</p> <p>—</p> <p>MR</p> <p>MR</p>
8	MOEFA			
		Required	provided	MR
9	Public Address System.			
		Not required	Not required	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	<p>—</p> <p>Required</p> <p>N/A</p>	<p>Sealed</p> <p>provided</p> <p>N/A</p>	<p>MR</p> <p>MR</p> <p>—</p>
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	—

[Handwritten signature]

	<ul style="list-style-type: none"> • Communication In lift Car 	W/A	W/A	-
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	W/A	W/A	-
	<ul style="list-style-type: none"> • Lift Signage 	W/A	W/A	-
17	Standby power supply	Required	84 KVA	MR
18	Refuge Area.			
	➤ Total Area	W/A	W/A	-
	➤ Location	W/A	W/A	-
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	W/A	W/A	-
	<ul style="list-style-type: none"> • Flow Switch Panel 	W/A	W/A	-
	<ul style="list-style-type: none"> • PA System Panel 	W/A	W/A	-
	<ul style="list-style-type: none"> • Batter backup 	W/A	W/A	-
	<ul style="list-style-type: none"> • Building Floor Plans 	W/A	W/A	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire extinguisher provided near elect. panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~renew~~/grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name
Designation

Signature of the Inspecting Officer

Name M. K. CHATTOPADHYAY
Designation ADO (HO)