

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 3097

Dated: 27/08/12

FIRE SAFETY CERTIFICATE

Certified that the Salute India Deluxe Guest House, 8182, Gali No.-6, Arakashan Road, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + 02 guest rooms), 1st floor to 4th floor (03 guest rooms at each floor) and terrace floor (02 staff rooms sealed with brick wall and lift machine room), total 14 guest rooms, was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/2174 dated 17-07-2009. The premises was re-inspected by the officer concerned of this department on 14-08-2012 in the presence of Sh. Sanjay Bansala (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 14 guest rooms with effect from 27/08/12, 2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 27/08/12 at New Delhi by.


27/8

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049: wrt...47002/Addl.CP/Lic.(H) dated 26-7-2012
2. M/s Salute India Deluxe Guest House, 8182, Gali No.-6, Arakashan Road, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Salute India Deluxe Guest House, 8182, Gali No-6, A.K. Road
2. Type of Occupancy : Lodging House
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. FG/DPS/MS/GH/2009/2174 Dated: 17-07-2009
5. Fire Safety directives letter No : NA
6. Date of inspection : 14-08-2012
7. Name of the Inspecting Officers : Sh. D.S. Yadav (A.D.O)
8. Name and designation of officers from the building side : Sh. Sanjay Bansala (owner)
9. Year of Construction : 2001 Starting Year in D.F.S
10. Applicant's letter No. : NIL dated 07/08/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR Old Case
1	Access to building			
	• Road width	N.A	More than 6 mtrs wide	MR ✓
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	80 Cms.	120 Cms.	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	01	MR ✓
	g. Width of Corridor	NA	NA	NA
	h. Door Size	NA	NA	NA

Contd. :-

old case

3	Compartmentation.			
	• Fire check door	NA	—	—
	• Sealing of electrical shafts	NA	—	—
	• Fire Rating of shaft door	NA	—	—
	• Water Curtain	NA	—	—
	• Fire Dampers	NA	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	12	12	MR
	• Types	—	Water Co ₂ & A.B.C	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	—	—
	• Location of Main Panel	NA	—	—
	• Location of Repeater Panel	NA	—	—
	• Alternate source of power	NA	—	—
	• Hooters' Location	NA	—	—
8	MOEFA			
		NA	—	—
9	Public Address System.			
		Yes	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	—	—

Contd.?

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	NA	—	—
		NA	—	—
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	—	—
		NA	—	—
		NA	—	—
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	—	—
		NA	—	—
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
		NA	—	—
	<ul style="list-style-type: none"> Terra e level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	225 LPM.	225 LPM.	MR
		30 Mtrs.	30 Mtrs.	MR
		Electric	Electric	MR
		—	Switch Provided at G.F.	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	NA	—	—
		NA	—	—

Salute India Dr. Guest House, 8182, Gali No.-6, A Sakshari Road,
Pahar Gaj, New Delhi - 110055

old case

	• Fire service inlet	NA	—	✓
	• Access to tank	NA	—	—
	• Overhead Tank capacity	2500 Ltrs.	2500 Ltrs.	MR
15	Exit Signage.	Yes	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	—	—
	• Pressurization of Lift lobby	NA	—	—
	• Communication In lift Car	Yes	Provided	MR
	• Fireman's Grounding Switch	Yes	Provided	MR
	• Lift Signage	Yes	Provided	MR
17	Standby power supply	Yes	D. G. Set.	MR
18	Refuge Area.			
	• Total Area	NA	—	—
	• Location	NA	—	—
19	Fire Control Room			
	• Detector System Panel	NA	—	—
	• Flow Switch Panel	NA	—	—
	• PA System Panel	NA	—	—
	• Batter backup	NA	—	—
	• Building Floor Plans	NA	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Contd. 7

Salute India Ex. Guest House, 8182, Gali No.-6, Arakshan Road,
Pahar Ganj, New Delhi - 110055

Signature of the Inspecting Officer

Name

Designation

D.O. (C.D.)

Signature of the Inspecting Officer

Name *Prasen vire Singh yadav*

Designation *Assistant Divisional Officer
(Central)*

Forwarded for approval please.

By CFO (NDZ)

11/11/12
21/8/12