

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No F 6 / DFS / MS / 2012 / EH / 3108

Dated 27 / 08 / 12

**FIRE SAFETY CERTIFICATE**

Certified that the Suribachi Restaurant located at T- 540/4, Malviya Nagar, New Delhi, comprised of Ground floor was granted NOC by this department vide letter No F6/ DFS/ MS/ EH/ 2009/ 2108 dated 15.07.2009. The premises was re-inspected by the officer concerned of this department on 18.08.2012 in the presence of Mr. Ghai and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from 27/08/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 27/08/12 at New Delhi by.



Chief Fire Officer  
Delhi Fire Service

9/CA

Copy to: -

1. The Asstt. Director (Tourism),  
Govt. of NCT of Delhi, Room No. 176, Old Sectt, Delhi-110054
2. Suribachi Restaurant, T- 540/4, Malviya Nagar, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be uses as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Old case  
Renewal

**INSPECTION REPORT**

1. Name & address of the building: M/S SURI BACHHI Restaurants  
T-540/4, Malviya Nagar
2. Type of Occupancy: Restaurant (Arms)
3. Type of Case: Renewal
4. Details of previous NOC: Letter No FC/DFS/AS/EM/2009/2100 dated 15/07/09
5. Fire Safety directives Letter No.: N/A
6. Date of inspection: 10/01/12
7. Name of the Inspecting Officer: S.S. KAUSHIK
8. Name and designation of Officer  
from the building side: MR Ghai - owner
9. Year of Construction: Before 2005
10. Applicant's letter No.: 7/08/12

Building plans ground floor only

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>N/A</u>		
	• Gate width	<u>N/A</u>		
	• Width of internal road	<u>N/A</u>		
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	<u>N/A</u>		
	• Upper floors	<u>N/A</u>		
	• Basements	<u>N/A</u>		
	b. Width of staircases			
	• Upper floors	<u>N/A</u>		
	• Basements	<u>N/A</u>		
	c. Protection of exits			
	• Fire check door	<u>N/A</u>		
	• Pressurization	<u>N/A</u>		
	d. No of continuous staircase to terrace	<u>N/A</u>		



	e. Width Of Corridor	N/A		
	f. Door Size	N/A		
3.	Compartmentation			
	• Fire check door	N/A		
	• Sealing of electrical shafts	N/A		
	• Fire Rating of shaft door	N/A		
	• Water Curtain	N/A		
	• Fire Dampers	N/A		
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	
	• Upper floors	12 a/c per hour	Yes	MR
5.	Fire Extinguishers			
	• Total numbers	8	Eight	MR
	• Types		WT, Co2	MR
	• IS marking	ISI marked	Yes	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	One	Yes	MR
	• Length of hose reel hose	30 ml	Yes	MR
	• Nozzle diameter	5mm	Yes	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A		
	• Location of Main Panel	N/A		
	• Location of Repeater Panel	N/A		
	• Alternate source of power	N/A		
	• Hooters' Location	N/A		
8.	MOEFA	Yes	Yes	MR
9.	Public Address System	N/A		
10.	Automatic Sprinkler System			
	• Basements	N/A		
	• Upper Floor	N/A		
	• Sprinkler above false ceiling	N/A		
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	Yes	MR

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	N/A		
12.	Yard Hydrants	N/A		
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N/A		
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual stopping</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 lpm	ys	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	39m	ys	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	ys	ys	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	ys	ys	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Draw of connection</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	5000 lts	5000 lts	MR
15	Exit Signage	ys	ys	ys
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Pressurization of lift lobby</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> </ul>	N/A		

	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	N/A		
17.	Standby power supply	N/A		
18.	Refuge Area	Y3	Y5	MR
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	N/A		
19.	Fire control room	N/A		
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>	N/A		
		N/A		
		N/A		
		N/A		
20.	Special Fire Protection Systems for Protection of special Risks, if any;	X		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....

Signature of the Inspecting Officer

Name

on leave

Designation

Signature of the Inspecting Officer

Name

S.S. Kaushik

Designation

AO/CC