

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001.


No. F.6/ DFS/ MS/ 2012/ 3053

Dated: 23/08/2012

FIRE SAFETY CERTIFICATE

Certified that the Temple Building located at Plot No.HAF-7, Sec-12, Dwarka, New Delhi, comprised of Basement + Ground + 01 Upper Floor owned / occupied by M/s M.R. Charitable Trust, was inspected by the officers concerned of this department on 26.07.2012 in the presence of Sh. Tarkashwar Pandey, Dr. D.N. Kalra (Secretary) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group - D Assembly Building Sub- Division D-3 with effect from 23/08/2012 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....23/08/12.....at New Delhi by.


23/8

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

etc
MNC

Copy to:-

1. The Joint Director (L&C), (Bldg),
DDA, Bldg Section, Vikas Sadan, INA, New Delhi.
 2. Dr. D.N. Kalra (Secretary)
M.R. Charitable Trust, B-4/200, Safdarjung Enclave, New Delhi-29
Conditions for the validity of fire safety certificate
1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
 2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
 3. The trained fire fighting staff should be available round the clock.
 4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
 5. The basement shall be uses as per the provisions of BBL.
 6. The fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
 7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Basement, Ground & First Floor

INSPECTION REPORT M.R. Charitable Trust

1. Name & address of the building : Temple at Plot No HAF-7, Sec-12, Dwarka, New Delhi
2. Type of Occupancy : Group D, Sub Div - D-3
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Date
5. Fire Safety directives letter No : F.G/DFS/MS/BP/2011/1017 dated 27.05.2011
6. Date of inspection : 26.07.2012
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Dr. D.N. Kalra (Sec.), Sh. Tarakswar Pandey
9. Year of Construction : 2011-2012
10. Applicant's letter No. : NIL dated. 06.06.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	30 mtr	MR
	• Gate width	-	06 mtr	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	MR
	• Basements	-do-	-do-	MR
	b. Width of staircases			
	• Upper Floor	150 cms Each	150 cms Each	(02 Nos. S. Cape) MR
	• Basements	-do-	-do-	MR
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace			
		-	One	-
	e. Width of Corridor	N/A	-	-
	f. Door Size	N/A	-	-
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	N/A	-	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are Provided	MR
	• Upper floors		Natural Ventilation	MR

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	08 Nos	Provided	MR
	• Types	A.B.C	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	N/A	-	-
	• Location of Repeater Panel	N/A	-	-
	• Alternate source of power	-	D.G. Set of 625 kva	-
	• Hooters' Location	-	In Staircase	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	Area less than 200 sq. m
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	100 M.M	100 M.M	MR
	• Number of hydrants per floor	-	One	MR
	• Hose Box	-	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-

Plot No. HAF-7, Sec-12,
Dwarka, New Delhi.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		900LPM, 180LPM	900LPM, 220LPM	MR
		30M Each Required	30M Each Provided	MR MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
		15000 Ltr	15000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- A statue of Lord Ganesh erected at the front side of the temple building as seen during the inspection.



Signature of Inspecting Officer

Name H. L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asst. Divisional Officer