

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2012 / E-1 / 3129

Dated 29/8/12

FIRE SAFETY CERTIFICATE

Certified that the KFC (Yum Restaurants India Pvt. Ltd.) located at M-55, Greater Kailash, Part - I, New Delhi, comprised of Ground + 02 Upper Floors but the restaurant is running on 1st & 2nd floor only owned occupied by Yum Restaurants India Pvt. Ltd., was inspected by the officers concerned of this department on 03.08.2012 in the presence of Mr. Harvinder and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group - D Assembly Building with effect from 29/8/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on29/08/12... at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer,
Health Department, South Zone, MCD, New Delhi.
2. KFC (Yum Restaurants India Pvt. Ltd.) M-55, Greater Kailash, Part - I, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be uses as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules' 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: KFC (Yum Restaurant India Pvt. Ltd.) M-55, Greater Kailash Part – I, New Delhi.
2. Type of Occupancy : Group – D, Assembly Building
3. Type of Case : New (restaurant is running since 2009)
4. Details of previous NOC : N/A
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 03.08.2012
7. Name of the Inspecting Officer : D.O. D.P. Bhardwaj & A.D.O. S.S. Kaushik
8. Name and designation of Officer
from the building side : Mr. Harvinder
9. Year of Construction : Before 1990
10. Applicant's letter No. : Nil Dated 12.06.2012 , Ground+2 Upper Floor but the restaurant is running on 1st & 2nd floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/As per Circular,356-369 dt. 22.03.05, by AS (Home) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	4.5 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	As per Circular dated. 22.03.2005	1.15 mtr. & 1 mtr.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	Yes	Provided	MR
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	01	01	MR
	f. Door Size/Nos.	N/A	N/A	N/A
		02	02	MR
3.	Compartmentation			
	• Fire check door	Yes	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	• Total numbers	ISI marked	08 Nos.	MR
	• Types		ABC, CO ₂ & W.CO ₂	MR
	• IS marking		Yes	Yes

6.	First-Aid Hose Reel			
	1) Total number of each floor	One at each floor	One at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Yes	MR
	2) Location of main panel	Maintained	Yes	MR
	3) Location of repeater panel	Maintained	Yes	MR
	4) Alternate source of power	Yes	Provided	MR
	5) Hooter's Location	Public area	Yes	MR
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	Yes	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Yes	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Yes	100 mm	MR
	2) Number of hydrants per floor	Yes	1 Nos.	MR
	3) Hose box	Yes	1 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM & 180 LPM	450 LPM & 180 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Yes	Provided	MR
	d) Auto starting of pump	Yes	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 Ltrs.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A

	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Case may kindly consider as restaurant building running since 2009 is an old case.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj

D.P. Bharadwaj

Name:- S.S. Kaushik.

S.S. Kaushik
14/8/12

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer.