

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

NO. F6/OFS/ms/school/2012/3185

DATED: 31/08/12

FIRE SAFETY CERTIFICATE

Certified that the Sirish Public School at B-210,Gali No.1,Rajveer Colony Extn.,Delhi-96,is running at ground plus two upper floors of the building comprised of ground plus three upper floors owned/occupied by Sirish Public School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 17.01.2005 and verified by the officer concerned of Fire Service on 27.03.2012& 17.08.12 in the presence of Smt. Shrivastva (Owner)of the school and ground, first & second floor of the building is fit for occupancy class B' Educational Building' with effect from ..31/08/12.... for a period of **three** years ,subject to conditions printed overleaf.

Issued on.....31/08/12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

jc  
Head  
29/8/12

To,  
The Head -Mistress  
Sirish Public School  
B-210,Gali No.1,Rajveer Colony Extn.,  
Delhi-96

Copy to:-  
The Director of Education  
Govt.of NCT of Delhi  
Old Secretariat, Delhi-51.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safet Ccertificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/C

## INSPECTION REPORT

1. Name & address of the building : Sirish Public School at B-210,Gali No.1,Rajveer Colony  
Extn.,Delhi-96.
2. Building is comprised of :Ground + three upper floors(School at G+2 floor only).
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC letter :Nil
6. Fire Safety direction letter No : Circular Director of Education dated 17.01.2005 ✓
7. Date of Inspection : 27.03.12 &17.8.12
8. Name of the Inspecting officers: DO Virendra Singh,
9. Name and designation of Officer:  
from the building side : Smt.Shrivastva
10. Year of Construction - :1998
11. Applicant's letter No : letter No.Nil dated 23.02.2012.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	-----	6 Mtrs.	MR
		-----	-----	-----
		-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	02 Nos.	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	02 Nos	02 Nos.	MR
		-----	-----	-----
	B. Width of Staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	-----	75 cm,90cm	MR
		-----	-----	-----
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	-----	-----	-----
		-----	-----	-----
	e. No. of continuous staircases to terrace	-----	1No.	MR
		-----	-----	-----
	g. Width of Corridor	-----	1.25 mts	MR



2/2

	h. Door Size	-----	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	-----	-----	-----
		-----	-----	-----
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> </ul>	4 Nos. ABC & Co2	6 Nos. ABC & Co2	MR MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no	1no Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	30 M 5 MM Provided Provided	MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of main panel</li> <li>• Location of repeater panel</li> <li>• Alternate source of power</li> </ul>	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
	<ul style="list-style-type: none"> <li>• Hooter's location</li> </ul>	-----	-----	-----
8	MOEFA	-----	-----	-----
9	Public address System.	-----	-----	-----
10	Automatic Sprinkler System.	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• upper floor</li> <li>• sprinkler above false ceiling</li> </ul>	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• size of riser/down-comer</li> <li>• Number of hydrants per floor</li> </ul>	100 MM 1No.	Provided Provided	MR MR

N/8

	• Hose Box	1No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	-----	Provided	MR
	• Overhead Tank capacity	5,000 ltrs.,	10,000 Ltrs.	MR
15	Exit Signage.	-----	-----	-----
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	-----	-----	-----
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----

2/9

19	Fire Control Room	-----	-----	-----
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

By CPO (NDZ)

Signature of the Inspecting Officer  
Name Virendra Singh  
Designation DO (B)