

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DFS/MS/school/2012/3269

Dated: 07/09/12

**FIRE SAFETY CERTIFICATE**

Certified that the AVB Adarsh Vidya Bhawan, plot No. 43, I.P. Extn. Near Bathla Apartment, Delhi - 92, comprised of ground plus three upper floors was granted NOC by this department vide Letter No- F6/DFS/MS/09/2610 dated 24.08.09. School building was re-inspected by the officer concerned of this department on 29.08.12 in the presence of Mrs. Ritu Verma Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Group B "Educational Building" with effect from ...07/09/12.. renewed for a period of three years, subject to conditions printed overleaf.

Issued on.....07/09/12.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

  
07/09/12

To,

The Principal  
AVB Adarsh Vidya Bhawan,  
Plot No. 43, I.P. Extn. Near Bathla Apartment, Delhi -92.

Copy to:-

The Joint Director of Education  
(Land & Estate)  
Directorate of Education,  
Lucknow Road, Delhi -54.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : AVB Adarsh Vidya Bhawan, plot No. 43, I.P. Extn. Near Bathla Apartment, Delhi -92.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : Letter No- F6/DFS/MS/09/2610 Dated 24.08.09
5. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
6. Date of Inspection : 29.08.12
7. Name of the Inspecting Officers: : Suresh singh (ADO)
8. Name of the designation of Officer  
from the building side : Mrs. Ritu Verma, Principal
9. Year of Construction : 1992
10. Applicant's letter No : dated 17.08.12
11. Building is comprised of : G+3

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	15 m	MR ✓
	Gate width	.....	.....	.....
	Width of internal road	.....	.....	.....
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	3 no.	3 no.	MR ✓
	Upper Floor	3 no.	3 no.	MR
	Basement	.....	.....	.....
	B. Width of Staircases	1.5 m	1.5 m each	MR ✓
	Upper Floor	1.5 m	1.5 m	MR
	Basement	.....	.....	.....
	c. Protection of exits	.....	.....	.....
	Fire check door	.....	.....	.....
	Pressurization	.....	.....	.....
	e. No. of continuous staircases to terrace	01 no.	01 no.	MR ✓
	g. Width of Corridor	1.5 m	2.2 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.	Required	Provided	
	Fire check door	.....	.....	.....
	Sealing of electrical shafts	.....	.....	.....
	Fire rating of shaft door	.....	.....	.....
	Water curtain	.....	.....	.....
	Fire Dampers	.....	.....	.....
4	Smoke Management System.	N/A		
	Basement	30a/c per hour	.....	.....
	Upper floor	12 a/c per hour	.....	.....

5.	Fire Extinguisher	Required		
	Total numbers	13 no.	13 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR ✓
	Length of hose reel hose	30 m	provided	MR
	Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors	.....	.....	.....
	Location of main panel	.....	.....	.....
	Location of repeater panel	.....	.....	.....
	Alternate source of power	.....	.....	.....
	Hooters's location	.....	.....	.....
8	MOEFA	.....	.....	.....
9	Public address System.	.....	Yes	.....
10	Automatic Sprinkler System.	N/A		
	basement	.....	.....	.....
	upper floor	.....	.....	.....
	sprinkler above false ceiling	.....	.....	.....
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR ✓
	Number of hydrants per floor	02 no.	02 no.	MR
	Hose Box	Required	Provided	MR
12	Yard Hydrants.	N/A		
	Total number of hydrants	.....	.....	.....
	Hose Box	.....	.....	.....
13	Pumping Arrangements.	Required		
	• Ground Level	.....	.....	.....
	➤ Discharge of main Pump	.....	.....	.....
	➤ Head of Main Pump	.....	.....	.....
	➤ Number of main pumps	.....	.....	.....
	➤ Jockey pump out put	.....	.....	.....
	➤ Jockey pump head	.....	.....	.....
	➤ Standby pump out put	.....	.....	.....
	➤ Standby pump Head	.....	.....	.....
	➤ Auto Starting /Manual stopping	.....	.....	.....
	➤ Pump House Access	.....	.....	.....
	• Terrace Level	.....	.....	.....
	➤ Discharge of pump	450 LPM	450 LPM	MR ✓
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	.....	.....	.....
	➤ Auto Starting of pump	.....	.....	.....

14	Captive Water Storage for Fire Fighting.	Required		
	Underground tank capacity →	-----	10000 Liters ✓	-----
	Draw-off connection	-----	-----	-----
	Fire service inlet	-----	-----	-----
	Access to tank	-----	-----	-----
	✓ Overhead Tank capacity	5000 Liters	5000 Liters	MR ✓
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft	-----	-----	-----
	Pressurization of Lift lobby	-----	-----	-----
	Communication in lift car	-----	-----	-----
	Firemen's grounding switch	-----	-----	-----
	Lift Signage	-----	-----	-----
17	Standby power supply	N/A	-----	-----
18	Refuge Area.	N/A		
	Total area	-----	-----	-----
	Location	-----	-----	-----
19	Fire Control Room	N/A		
	Detector system panel	-----	-----	-----
	Flow switch panel	-----	-----	-----
	PA system panel	-----	-----	-----
	Batter backup	-----	-----	-----
	Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	-----	-----

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*S Singh*

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO

Do East

*Mugh*  
5/9/12