

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/OFS/MS/FW/2012/3306

Dated 11/09/12

FIRE SAFETY CERTIFICATE

Certified that the M/S Angad Fireworks Prop. Ravi Jain at Shop No. A – 1/9, Kabir Nagar, Main 100 ft. Road, Delhi-94, comprised of ground floor owned/occupied by M/S Angad Fireworks have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of Fire Service on dated 18.08.12 in the presence of Sh. Ravi Jain, and that the building is fit for occupancy class Fireworks storage with effect from 11/09/12 for a period of three years, subject to conditions printed overleaf.

Issued on 11/09/12 at New Delhi by



Chief Fire Officer
Delhi Fire Service



10.9.12

To,

The Additional Commissioner of police (Licensing),
1st Floor, P.S. Defence colony,
New Delhi.

Copy to:-

Sh. Ravi Jain S/O Sh. Bhupender Kumar Jain
1/1593, Mansarover Park, Shahdara, Delhi -32.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Angad Fireworks at Shop no. A-1/9, Kabir Nagar,
100 Ft. Road, Delhi-94.
2. Type of Occupancy : Storage Fireworks
3. Type of Case : New Case
4. Details of Previous NOC : Nil
5. Fire Safety direction letter No : -----
6. Date of Inspection : 18.08.12
7. Name of the Inspecting Officers : DO Virendra Singh
8. Name of the Person from the : Mr. Ravil Jain
Building side
9. Year of Construction : 2005
10. Reference/Licensing deptt. letter no. (PFW/15)/2012/47268 - 70/Addl.Cp/Lic.(Expl.)

Dated 27.07.12

| S.NO. | Point of Inspection | Requirement | At Site | Remarks MR/NMR |
|-------|--|--|----------------------|----------------|
| 1 | Type of construction and floor area & floor level | | | |
| | a. Minimum floor area | 9m ² (Min.) ^{to} -25M ² | 22.98 M ² | MR ✓ |
| | b. Construction | Pucca | Provided | MR ✓ |
| | c. Premises Location | Not under the staircase/Mean ¹⁰⁰ of escape | Provided | MR ✓ |
| | d. Business permissible only at ground floor level | Required | Provided | MR ✓ |
| | e. Business from pavement of road prohibited | prohibited | Yes | MR |
| 2 | Entrance & Exits to the licensed premises | | | |
| | The licensed premises shall have independent entrance and exit | Required | Provided (Yes) | MR |

| | | | | |
|----|--|---|--------------------------------|------|
| 3 | Type and distance of the surrounding risk | | | |
| | The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/ inflammable or hazardous materials. | Required 15 m | Provided | MR ✓ |
| 4 | Nature of business run in the licensed premises | | | |
| | The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes. | Required | Provided (yes) | MR |
| 5. | Type of electrical wiring and electrical fittings | | | |
| | a. Preferably concealed or through conduit | Required | Provided | MR |
| | b. All electrical fitting should be flame/spark proof | Required | Provided with casing & capping | MR |
| 6 | Extension of Shop for Business. | | | |
| | Prohibited | Prohibited | Yes | MR |
| 7 | Approach Road | | | |
| | The road width on the side of which premises is located should be 12m. | 12 M | 30 M | MR ✓ |
| 8 | Fire Protection Arrangement. | | | |
| | a) Extinguishers (Type & No's.) | 2 nos. water type & 1 no. of ABC/Co2 type | Provided | MR ✓ |
| | b) Sand and Water Buckets | 2 nos. each | Provided | MR ✓ |
| | c) Water Drum(s) | 1 nos. | Provided | MR ✓ |
| 9 | Any other point that is contrary to the safety of people. | | | |

The fire protection systems provided in shop were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
Name VIRENDRA SINGH
DO (E)

Dy CPO (NDZ)