

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DPS/MS/School/2012/3242

Dated: 05/08/12

FIRE SAFETY CERTIFICATE

Certified that the Nagar Nigam Prathmic Vidyalaya, Chand Mohalla, Gandhi Nagar, Delhi-31, comprised of ground floor only owned/occupied by Nagar Nigam Prathmic Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 17.08.12 in the presence of Mr. Brijpal Kaushik, Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 05/08/12 for a period of **three** years, subject to conditions printed overleaf.

Issued on.....05/08/12.....at New Delhi by



Chief Fire Officer
Delhi Fire Service



To,

The Principal (1st Shift)
Nagar Nigam Prathmic Vidyalaya,
Chand Mohalla, Gandhi Nagar, Delhi-31.

Copy to:-

1. The Director of Education,
MCD, Nigam Bhawan, Kashmiri Gate, Delhi
2. The Principal (2nd Shift)
Nagar Nigam Prathmic Vidyalaya,
Chand Mohalla, Gandhi Nagar, Delhi-31

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

12W-3

INSPECTION REPORT

1. Name & address of the building : Nagar Nigam Prathmic Vidyalaya, Chand Mohalla, 2nd Shift, Gandhi Nagar, Delhi-31
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- _____ Dated _____
5. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
6. Date of Inspection : 17.08.12
7. Name of the Inspecting Officers: : Suresh singh (ADO)
8. Name of the designation of Officer from the building side : Mr. Brijpal Kaushik, Principal
9. Year of Construction : 1974
10. Applicant's letter No : dated 17.08.12

(Grand only)

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	8 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases
	Upper Floor
	Basement
	B. Width of Staircases
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
g. Width of Corridor	1.5 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.	Required	Provided	
	• Fire check door
	• Sealing of electrical shafts
	• Fire rating of shaft door
	• Water curtain
	• Fire Dampers
4	Smoke Management System.	N/A		
	• Basement	30a/c per hour
	• Upper floor	12 a/c per hour

1 RN-4

5.	Fire Extinguisher			
	• Total numbers	02 no.	04 no.	MR
	• Types	Co2 & ABC	Co2 & ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.	N/A		
	Total numbers of each floor
	Length of hose reel hose	30 m
	Nozzle diameter	5 mm
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Yes
9	Public address System.	N/A
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	N/A		
	size of riser/down-comer
	Number of hydrants per floor
	Hose Box
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	N/A		
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump
	➤ Head of the Pump
	➤ Power supply

NAGAR NIGAM PRATHMIC VIDHYALAYA
 CHAND MOHALLA 2ND ST. FT.
 GANDHI NAGAR

1 RN-5

	➤ Auto Starting of pump
14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity
15	Exit Signage.	N/A		
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A		
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

S Singh

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*

DO/ES

Forwarded for approval please.

Mugh
22/01/12