

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DAS/ms/school/2012/3243

Dated: 05/08/12

FIRE SAFETY CERTIFICATE

Certified that the Nagar Nigam Prathmic Sah Shiksha Vidyalaya, Geeta Colony, Block-5, Delhi-31, comprised of ground plus one upper floor owned/occupied by Nagar Nigam Prathmic Sah Shiksha Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 17.08.12 in the presence of Mrs. Darshan Kumari Gupta, Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 05/08/12 for a period of **three** years, subject to conditions printed overleaf.

Issued on 05/08/12 at New Delhi by



Chief Fire Officer
Delhi Fire Service

To,

The Principal (1st Shift)
Nagar Nigam Prathmic Sah Shiksha Vidyalaya,
Geeta Colony, Block-5, Delhi-31.

Copy to:-

1. The Director of Education,
MCD, Nigam Bhawan, Kashmiri Gate, Delhi.
2. The Principal (2nd Shift)
Nagar Nigam Prathmic Sah Shiksha Vidyalaya,
Geeta Colony, Block-5, Delhi-31.



INSPECTION REPORT

1. Name & address of the building : Nagar Nigam Prathmic Sah Shiksha Vidyalaya, Geeta Colony, Block-5, 1st Shift, Delhi-31
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- _____ Dated _____
5. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated. 01.03.11
6. Date of Inspection : 17.08.12
7. Name of the Inspecting Officers: : Suresh singh (ADO)
8. Name of the designation of Officer from the building side : Mrs. Darshan Kumari Gupta, Principal
9. Year of Construction : 2004
10. Applicant's letter No : dated 17.08.12

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 no.	2 no.	MR
	Upper Floor
	Basement
	B. Width of Staircases	1.7 m each	MR
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
	g. Width of Corridor
	h. Door Size	1.5 m	2.4 m	MR
		1 m	1 m	MR
3	Compartmentation.	Required	Provided	
	• Fire check door
	• Sealing of electrical shafts
	• Fire rating of shaft door
	• Water curtain
	• Fire Dampers
4	Smoke Management System.	N/A		
	• Basement	30a/c per hour
	• Upper floor	12 a/c per hour



5.	Fire Extinguisher			
	<ul style="list-style-type: none"> Total numbers 	03 no.	04 no.	MR
	<ul style="list-style-type: none"> Types 	Co2 & ABC	Co2 & ABC	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.	N/A		
	Total numbers of each floor
	Length of hose reel hose	30 m
	Nozzle diameter	5 mm
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Yes
9	Public address System.	Yes
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	N/A		
	size of riser/down-comer
	Number of hydrants per floor
	Hose Box
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	N/A		
	<ul style="list-style-type: none"> Ground Level
	<ul style="list-style-type: none"> ➤ Discharge of main Pump
	<ul style="list-style-type: none"> ➤ Head of Main Pump
	<ul style="list-style-type: none"> ➤ Number of main pumps
	<ul style="list-style-type: none"> ➤ Jockey pump out put
	<ul style="list-style-type: none"> ➤ Jockey pump head
	<ul style="list-style-type: none"> ➤ Standby pump out put
	<ul style="list-style-type: none"> ➤ Standby pump Head
	<ul style="list-style-type: none"> ➤ Auto Starting /Manual stopping
	<ul style="list-style-type: none"> ➤ Pump House Access
	<ul style="list-style-type: none"> Terrace Level
	<ul style="list-style-type: none"> ➤ Discharge of pump
	<ul style="list-style-type: none"> ➤ Head of the Pump
	<ul style="list-style-type: none"> ➤ Power supply

	➤ Auto Starting of pump
14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity
15	Exit Signage.	N/A
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
Signature of the Inspecting Officer
Name SURESH SINGH
Designation ADO

DO (east)

Forwarded for approval please.

Dy CEO/NITD

N Singh
20/8/12