

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFSS/MS/School/2012/3240

Dated: 05/09/12

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary School Ramesh Park, Laxmi Nagar Delhi-92, comprised of ground floor only owned/occupied by M.C. Primary School, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 24.08.12 in the presence of Mr. Parvez Javed, Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 05/09/12 for a period of **three** years, subject to conditions printed overleaf.

Issued on 05/09/12 at New Delhi by




Chief Fire Officer
Delhi Fire Service

To,

The Principal (1st Shift)
M.C. Primary School,
Ramesh Park, Laxmi Nagar Delhi-92

Copy to:-

1. The Director of Education,
MCD, Nigam Bhawan, Kashmiri Gate, Delhi.
- ✓ 2. The Principal (2nd Shift)
M.C. Primary School,
Ramesh Park, Laxmi Nagar Delhi-92.



CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M.C. Primary School, Ramesh Park, Laxmi Nagar, Delhi-92.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- _____ Dated _____
5. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
6. Date of Inspection : 24.08.12
7. Name of the Inspecting Officers: : Suresh singh (ADO)
8. Name of the designation of Officer
from the building side : Mr. Parvez Javed, Principal
9. Year of Construction : 2004
10. Applicant's letter No : Nil

(Gangy)

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases
	Upper Floor
	Basement
	B. Width of Staircases
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
g. Width of Corridor	1.5 m	1.5 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.	Required	Provided	
	• Fire check door
	• Sealing of electrical shafts
	• Fire rating of shaft door
	• Water curtain
	• Fire Dampers
4	Smoke Management System.	N/A		
	• Basement	30a/c per hour
	• Upper floor	12 a/c per hour

	➤ Auto Starting of pump
14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity
15	Exit Signage.	N/A
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
Name *Sunesh Singh*
Designation *AO*

DO (East) Forwarded for approval please.
25/01/12
By CPD/ENDZO