

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DAS/MS/school/2012/ 3238

Dated: 05/09/12

FIRE SAFETY CERTIFICATE

Certified that the Nagar Nigam Pratibha Balika Vidyalaya, Shastri Nagar, Delhi-31, comprised of ground plus one upper floor only owned/occupied by Nagar Nigam Pratibha Balika Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 17.08.12 in the presence of Mrs. Kiran Kumari, Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 05/09/12... for a period of **three** years, subject to conditions printed overleaf.

Issued on 05/09/12 at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

To,

The Principal (1<sup>st</sup> Shift)  
Nagar Nigam Pratibha Balika Vidyalaya,  
Shastri Nagar, Delhi-31.

Copy to:-

1. The Director of Education,  
MCD, Nigam Bhawan, Kashmiri Gate, Delhi
2. The Principal (2<sup>nd</sup> Shift)  
Nagar Nigam Pratibha Bal Vidyalaya,  
Shastri Nagar, Delhi-31.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : Nagar Nigam Pratibha Balika Vidyalaya, Shastri Nagar, Delhi-31
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- \_\_\_\_\_ Dated \_\_\_\_\_
5. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
6. Date of Inspection : 16.08.12
7. Name of the Inspecting Officers : ADO Suresh singh
8. Name of the designation of Officer  
From the building side : Mrs. Kiran Kumari, Principal
9. Year of Construction : 2004
10. Applicant's letter No : dated 17.08.12

(G + 1st floor)

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	.....	.....	.....
	Width of internal road	.....	.....	.....
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	..... ?	1 no.	MR
	Upper Floor	.....	.....	.....
	Basement	.....	.....	.....
	B. Width of Staircases	1.5 m	1.5 m each	MR
	Upper Floor	.....	.....	.....
	Basement	.....	.....	.....
	c. Protection of exits	.....	.....	.....
	Fire check door	.....	.....	.....
	D .Pressurization	.....	.....	.....
	e. No. of continuous staircases to terrace	.....	.....	.....
	g. Width of Corridor	1.5 m	1.6 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.	Required	Provided	
	Fire check door	.....	.....	.....
	Sealing of electrical shafts	.....	.....	.....
	Fire rating of shaft door	.....	.....	.....
	Water curtain	.....	.....	.....
	Fire Dampers	.....	.....	.....
4	Smoke Management System.	N/A		
	Basement	30a/c per hour	.....	.....
	Upper floor	12 a/c per hour	.....	.....
5.	Fire Extinguisher	Required		
	Total numbers	04 no.	04 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	ISI marking	ISI marked	ISI marked	MR

✓



6	First-aid-Hose Reels.	N/A		
	Total numbers of each floor	.....	.....	.....
	Length of hose reel hose	30 m	.....	.....
	Nozzle diameter	5 mm	.....	.....
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors	.....	.....	.....
	Location of main panel	.....	.....	.....
	Location of repeater panel	.....	.....	.....
	Alternate source of power	.....	.....	.....
	Hooters's location	.....	.....	.....
8	MOEFA	.....	Yes	.....
9	Public address System.	.....	Yes	.....
10	Automatic Sprinkler System.	N/A		
	basement	.....	.....	.....
	upper floor	.....	.....	.....
	sprinkler above false ceiling	.....	.....	.....
11	Internal Hydrants	N/A		
	size of riser/down-comer	.....	.....	.....
	Number of hydrants per floor	.....	.....	.....
	Hose Box	.....	.....	.....
12	Yard Hydrants.	N/A		
	Total number of hydrants	.....	.....	.....
	Hose Box	.....	.....	.....
13	Pumping Arrangements.	N/A		
	Ground Level	.....	.....	.....
	Discharge of main Pump	.....	.....	.....
	Head of Main Pump	.....	.....	.....
	Number of main pumps	.....	.....	.....
	Jockey pump out put	.....	.....	.....
	Jockey pump head	.....	.....	.....
	Standby pump out put	.....	.....	.....
	Standby pump Head	.....	.....	.....
	Auto Starting /Manual stopping	.....	.....	.....
	Pump House Access	.....	.....	.....
	Terrace Level	.....	.....	.....
	Discharge of pump	.....	.....	.....
	Head of the Pump	.....	.....	.....
	Power supply	.....	.....	.....
	Auto Starting of pump	.....	.....	.....
14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity	.....	.....	.....
	Draw-off connection	.....	.....	.....
	Fire service inlet	.....	.....	.....
	Access to tank	.....	.....	.....

	Overhead Tank capacity	.....	.....	.....
15	Exit Signage.	N/A	.....	.....
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft	.....	.....	.....
	Pressurization of Lift lobby	.....	.....	.....
	Communication in lift car	.....	.....	.....
	Firemen's grounding switch	.....	.....	.....
	Lift Signage	.....	.....	.....
17	Standby power supply	.....	.....	.....
18	Refuge Area.	N/A		
	Total area	.....	.....	.....
	Location	.....	.....	.....
19	Fire Control Room	N/A		
	Detector system panel	.....	.....	.....
	Flow switch panel	.....	.....	.....
	PA system panel	.....	.....	.....
	Batter backup	.....	.....	.....
	Building Floor Plans	.....	.....	.....
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	.....	.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Singh*  
27.8.12

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*

*DO (East)*

*Forwarded for approval please*

*Singh*  
28/01/12

*Document No 72*