

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2012/3285

Dated: 07/09/2012

FIRE SAFETY CERTIFICATE

Certified that the M.C.Primary School, is comprised of Ground floor S P S rooms (four block having 08 class rooms) located at Snivaji Park, New Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 16/08/2012 in the presence of Smt Poonam Bhatla, Teacher and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 07/09/12 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 07/09/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, M.C.Primary School, Shivaji Park, New Delhi
2. The Director of Education, Old Secretariat, Delhi



(GF only) on Block.

INSPECTION REPORT

1. Name & address of the building: MC Primary school, Shivaji Park, ND
2. Type of Occupancy : school
3. Type of Case : new
4. Details of previous NOC : Letter No
5. Fire Safety directives Letter No. : Dir of Edu CWO dtd 1/3/11
6. Date of inspection : 16/8/12
7. Name of the Inspecting Officer : ADO SSTuli
8. Name and designation of Officer Smt Poonam Bhatia (Teacher)
from the building side
9. Year of Construction : 1962
10. Applicant's letter No. : 17/07/12

No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
	Access of building			
	• Road width	<u>6 mtr</u>	<u>m/R</u>	<u>m/R</u>
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
	Number, width, Type & Arrangements of exits			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	b. Width of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	d. No of continuous staircase to terrace	<u>-</u>	<u>-</u>	<u>-</u>

	e. Width Of Corridor			
	f. Door Size	1 mtr	1 mtr	m/r
3.	Compartmentation			
	• Fire check door	N/R		
	• Sealing of electrical shafts	- " -		
	• Fire Rating of shaft door	- " -		
	• Water Curtain	- " -		
	• Fire Dampers	- " -		
4.	Smoke managements System	N/R	N/P	N/A
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers		Regd @ IFEJW 30 m ² Area	m/r
	• Types		04 ABC	m/r
	• IS marking	ISI marked	Yes	m/r
6.	First - Aid Hose Reels	N/R	N/P	m/r
	• Total numbers on each floor	-	-	m/r
	• Length of hose reel hose	-	-	-
	• Nozzle diameter	-	-	-
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA	-	-	-
9.	Public Address System	-	-	-
10.	Automatic Sprinkler System	-	-	-
	• Basements	-	-	-
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants	-	-	-
	• Size of riser/down- comer	-	-	-

	Number of hydrants per floor	N/A	NP	N/A
	• Hose Box	-	-	-
	Yard Hydrants	-	-	-
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements	-	-	-
	• Ground Level	-	-	-
	• Discharge of main pump	-	-	-
	➤ Head of main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	• Terrace level	-	-	-
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power supply	-	-	-
	➤ Auto starting of pump	-	-	-
14.	Captive water Storage for fire fighting	-	-	-
	• Under ground tank capacity	-	-	-
	➤ Draw of connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-
15	Exit Signage	-	-	-
16.	Provision of Lifts.	-	-	-
	➤ Pressurization of Lift Shaft	-	-	-
	➤ Pressurization of lift lobby	-	-	-
	➤ Communication in lift Car	-	-	-

	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch ➤ Lift Signage 	N/R	N/P	N/A
17.	Standby power supply	—	—	—
18.	Refuge Area	—	—	—
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	—	—	—
19.	Fire control room	—	—	—
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 	—	—	—
20.	Special Fire Protection Systems for Protection of special Risks, if any;	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation

20 (M/N)

Signature of the Inspecting Officer

Name

Designation

16/8/12
S.S. Tuli
ADO (M/N)