

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 3302

Dated: 11/09/12

FIRE SAFETY CERTIFICATE

Certified that the Rajdeep Dx. Guest House, 5611, Basant Road, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + 04 guest rooms), 1st floor (03 guest rooms + 01 office), 2nd floor to 3rd floor (03 guest rooms at each floor), total 13 guest rooms, was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/2985 dated 09-10-2009. The premises was re-inspected by the officer concerned of this department on 05-09-2012 in the presence of Sh. Raj Kumar Arora (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 13 guest rooms with effect from 11/09/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 11/09/12 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi - 110049 w.r.t. letter No.42282/Addl.CP/Lic.(H) dated 02-07-2012.
2. M/s Rajdeep Dx. Guest House, 5611, Basant Road, Pahar Ganj, New Delhi-110055.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Rajdeep Dv. Guest House, 5C11, Basant Road, Pahar Ganj, New Delhi - 110055
2. Type of Occupancy : Lodging House
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FG/DFS/MS/GH/2009/2985 Dated: 09-10-2009
5. Fire Safety directives letter No : -NA-
6. Date of inspection : 05-09-2012
7. Name of the Inspecting Officers : Sh. D.S. Yadav (A.D.O)
8. Name and designation of officers from the building side : Sh. Raj Kumar Arora (owner)
9. Year of Construction : 2001 Starting Year
10. Applicant's letter No. ^{Addl. C.P. Lic.} : 42282/Addl. C.P./Lic. (H) New Delhi Dated. 2/7/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	Access to building		(P.S.S. Area)	MR/NMR (Old Case)
	• Road width	- N.A -	02 M. tes approx wide gate	M.R
	• Gate width	- N.A -		
	• Width of internal road	- N.A -		
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	- N.A -		
b.	Width of staircases			
	• Upper Floors	80 Cms.	118 Cms.	MR ✓
	• Basements	- N.A -		
c.	Protection of exits			
	• Fire check door	- N.A -		
	• Pressurization	- N.A -		
e.	No. of continuous staircases to terrace	01	01	MR
g.	Width of Corridor	- N.A -		
h.	Door Size	- N.A -		

Contd. ↓

M/10

Rajdeep Dr. Guest House, 5611, Babant Road, Pahar Ganj, New Delhi-110055

old case

3	Compartmentation.			
	• Fire check door	— N.A. —		
	• Sealing of electrical shafts	— N.A. —		
	• Fire Rating of shaft door	— N.A. —		
	• Water Curtain	— N.A. —		
	• Fire Dampers	— N.A. —		
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	10	10	MR
	• Types		Water Co2 & A.B.C	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	— N.A. —		
	• Location of Main Panel	— N.A. —		
	• Location of Repeater Panel	— N.A. —		
	• Alternate source of power	— N.A. —		
	• Hooters' Location	— N.A. —		
8	MOERA	— N.A. —		
9	Public Address System.	Yes	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	— N.A. —		

Contd. 1

X

old case

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -		
		- N.A -		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	- N.A -		
		- N.A -		
		- N.A -		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -		
		- N.A -		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terra e level Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		225 LPM	225 LPM	MR
		30 Mtrs.	30 Mtrs.	MR
		Electric	Electric	MR
		-	Switch Provided at G.F.	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -		
		- N.A -		

Contd.'s

M/12

Rajdeep Ds. Guest House, 5611, Basant Road, Pahar Ganj, New Delhi - 110055

NDM

old case

	• Fire service inlet	- N.A -		
	➤ Access to tank	- N.A -		
	• Overhead Tank capacity	2500 Ltas.	2500 Ltas.	MR. ✓
15	Exit Signage.	Yes	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	- N.A -		
	• Pressurization of Lift lobby	- N.A -		
	• Communication In lift Car	- N.A -		
	• Fireman's Grounding Switch	- N.A -		
	• Lift Signage	- N.A -		
17	Standby power supply	Yes	D. G. Set	MR
18	Refuge Area.			
	➤ Total Area	- N.A -		
	➤ Location	- N.A -		
19	Fire Control Room			
	• Detector System Panel	- N.A -		
	• Flow Switch Panel	- N.A -		
	• PAi System Panel	- N.A -		
	• Batter backup	- N.A -		
	• Building Floor Plans	- N.A -		
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

Contd. 1

M113

Rajdeep Ds. Guest House, 5611, Basant Road, Pahar Ganj, New Delhi-110035

Signature of the Inspecting Officer

Name

Designation

D.O. (C.O.)

Recommended please.

Dy CFO (NDZ)

100

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional
Officer (Central)

05-04-12

6/9/12