

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 3299

Dated: 10/09/12

FIRE SAFETY CERTIFICATE

Certified that the Rajdeep Guest House, 5611-12, Basant Road, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + 01 office), 1st floor to 3rd floor (04 guest rooms at each floor), total 12 guest rooms, was granted NOC by this department vide letter No.F6/MS/DFS/GH/2009/2252 dated 24-07-2009. The premises was re-inspected by the officer concerned of this department on 04-09-2012 in the presence of Sh. Rajkumar Arora (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 12 guest rooms with effect from 10/09/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 10/09/12 at New Delhi by.

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.w.r.t. No.41807/Addl.C.P./Lic.(H) New Delhi dated 29-06-12
2. M/s Rajdeep Guest House, 5611-12, Basant Road, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

Rajdeep Guest House, 5611-12, Bagant Road,

1. Name & address of the building : Pahar Ganj, New Delhi - 110055.
2. Type of Occupancy : Lodging house
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No FG/DFS/MS/GH/2009/2252 Dated 24-07-2009.
5. Fire Safety directives letter No : - N.A. -
6. Date of inspection : 04-09-2012.
7. Name of the Inspecting Officers : Dharmvir Singh Yadav.
8. Name and designation of officers from the building side : Shri Raj Kumar Arora (owner)
9. Year of Construction : 1981
10. Applicant's letter No. 41807/Addr. c. P. (etc) New Delhi the dated 29-06-12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/DBL Requirement	Provided at site	Remarks M/R/NMR old case
Access to building				
	• Road width	- N.A. -	more than 6 mtrs approx.	M.R
	• Gate width	- N.A. -	- N.A. -	- N.A. -
	• Width of internal road	- N.A. -	- N.A. -	- N.A. -
Number, Width, Type & Arrangement of Exits				
a. Number of staircases				
	• Upper Floors	one	one	M.R
	• Basements	- N.A. -	- N.A. -	- N.A. -
b. Width of staircases				
	• Upper Floors	0.80 mtr	101 cms to 103 cms	M.R ✓
	• Basements	- N.A. -	- N.A. -	- N.A. -
c. Protection of exits				
	• Fire check door	- N.A. -		
	• Pressurization	- N.A. -		
e. No. of continuous staircases to terrace				
		one	one	M.R
g. Width of Corridor				
		- N.A. -		
h. Door Size				
		- N.A. -		

contd:-

119
 Rajdeep guest house, 5611-12,
 Basant Road, Patah Gari,
 New Delhi-110055.

3	Compartmentation.			
	• Fire check door	- N.A -		
	• Sealing of electrical shafts	- N.A -		
	• Fire Rating of shaft door	- N.A -		
	• Water Curtain	- N.A -		
	• Fire Dampers	- N.A -		
4	Smoke Management System.			
	• Basements	30 a/c per hour	- N.A -	- N.A -
	• Upper floors	12 a/c per hour	natural ventilation	M.R
5	Fire Extinguishers			
	• Total numbers	08 nos	08 nos.	M.R
	• Types	-	CO ₂ type & w. CO ₂ type	M.R
	• IS marking	ISI marked	Provided	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one	one	M.R
	• Length of hose reel hose	30 m	Provided	M.R
	• Nozzle diameter	5 mm	Provided	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors	- N.A -		
	• Location of Main Panel	- N.A -		
	• Location of Repeater Panel	- N.A -		
	• Alternate source of power	- N.A -		
	• Hooters' Location	- N.A -		
8	MOERA	- N.A -	N.A	N.A
9	Public Address System.	N.A	Provided	M.R
10	Automatic Sprinkler System.			
	• Basement	- N.A -	- N.A -	- N.A -

contd. ✓

H/10 Rajdeep Guest house, 56/11-12,
 Basant Road, Patel Grant,
 New Delhi-110055

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -		
		- N.A -		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	- N.A -		
		- N.A -		
		- N.A -		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -		
		- N.A -		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		180 LPM	180 LPM	M.R
		30 mtrs	30 mtrs	M.R
		Electricity	Electricity	M.R
		-	switch provided at ground floor	M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -		
		- N.A -		

contd:-

X

N/M

Rajdeep guest house, 56/11-12,
Basant Road, Palika GATE, New Delhi-
110055

	• Fire service inlet	- N.A -		
	➤ Access to tank	- N.A -		
	• Overhead Tank capacity	2500 litres	2500 litres	M.R ✓
15	Exit Signage.	yes	Provided.	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	- N.A -		
	• Pressurization of Lift lobby	- N.A -		
	• Communication In lift Car	- N.A -		
	• Fireman's Grounding Switch	- N.A -		
	• Lift Signage	- N.A -		
17	Standby power supply	yes	D.G. set	M.R
18	Refuge Area.			
	➤ Total Area	- N.A -		
	➤ Location	- N.A -		
19	Fire Control Room			
	• Detector System Panel	- N.A -		
	• Flow Switch Panel	- N.A -		
	• PA System Panel	- N.A -		
	• Batter backup	- N.A -		
	• Building Floor Plans	- N.A -		
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

contd:-

M/12

Rajdeep guest house, 56/11-12,
Basant Road, Patel Garh,
New Delhi-110055

Signature of the Inspecting Officer

Rajdeep
04-09-12
Signature of the Inspecting Officer

Name

Name Drasm vis Singh yadav.

Designation

Designation A.D.O. (central)

D.O. (central)

Forwarded for approval please.

By CFB (NDZ)

Vijay
6/9/12