

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/ *School 13410*

Dated: *18/09/12*

FIRE SAFETY CERTIFICATE

Certified that the *Nigam Prati-bha Co-Ed School, Sultan Pur Mazra*
Delhi 110086
Prati-bha Co-Ed School comprised of *Ground floor only*
..... owned/occupied by *Nigam*
..... Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated: 01/03/2011 and
verified by the officer concerned of Fire Service on *16/8/12* in the presence of
Sh. T. Lok Chand and that the building/premises is fit for occupancy
Educational building with effect from *18/09/12* for a period of
03 years. In accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *18/09/12* at New Delhi.

Copy to:-

1. *The Principal*
Nigam Prati-bha Co-Ed School
Sultan Pur Mazra Delhi

2. *The Director Edu.*
MCD Civic Centre
Minto Rd. N. Delhi

[Signature]
148
Chief Fire Officer
Delhi Fire Service

OK *[Signature]*

Note:- This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NOC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

11N

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Co. Ed. School, Sultanpur Marg, - Delhi - 88.
2. Type of Occupancy : Educational.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : Dir. of Edun. (Circular)
6. Date of inspection : 16-8-2012.
7. Name of the Inspecting Officers : _____
8. Name and designation of officers : Sh. Tirlak Chand (Principal)
from the building side
9. Year of Construction : 1958, 1969, 1989. (Racca & sheds, G.F. only)
10. Applicant's letter No. : Nil dt. 23-7-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edun. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>6 m</u>	<u>M/R</u>
	• Gate width		<u>N/A</u>	
	• Width of internal road		<u>N/A</u>	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		<u>N/A</u>	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1 m</u>	<u>1.05 m</u>	<u>M/R</u>

21 M

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				N/A
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			N/A
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2 ABC or CO ₂ (25 kg) ISI marked	2 ABC yes		NIR NIR NIR
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm			NIR
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				NIR
8	MOEFA				NIR
9	Public Address System.				NIR
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 				NIR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		NIR	
11	Internal Hydrants		NIR	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.		NIR	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.		NIR	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.		NIR	
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NIR	
15	Exit Signage.		NIR	
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		NIR	
18	Refuge Area.		N/A	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		NIR	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/C	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.

D.D. (W)
 D-1 C.F. (W)
 C/o 2878
 29/8
 29/8

Smyal
 17/8/2012
 (S.W.A.M. LAL)
 Assit. Divn. Officer

F.T. M. S. cell