

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Motel/2012/3418 Dated: 18 / 09 / 2012

FIRE SAFETY CERTIFICATE

Certified that the **Pashupati Nath Resort** Kh. No.30-37, Village Jindpur Main G.T. Karnal. Road, New Delhi., comprised of basement, ground floor only with covered area of 2569.2m², 2585.43m², was granted NOC by this department vide letter No. **F6/DFS/MS/GH/2009/2575** dated **11/08/2009**. The premises was re-inspected by the officers concerned of this department on **27/08/2012** in the presence of **Mr. Rohit Gupta** of the **Pashupati Nath Resort** and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-A-1 (i) residential** occupancy with effect from ...18/09/12... for a period of three years subject to conditions printed over leaf.

Issued on...18/09/12...at New Delhi by



Chief Fire Officer
Delhi Fire Service

ok

Copy to:

1. Mr. Rohit Gupta
Pashupati Nath Resort Kh. No.30-37, Village Jindpur Main G.T. Karnal. Road, New Delhi
2. Add. Commissioner of Police Licensing Unit
1st Floor, PS Defence Colony, New Delhi

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no.42286/Addl. C.P./Lic(H) dated 02/07/12 received from the Addl. Commissioner of Police, regarding renewal of NOC in r/o Pashupati Nath Resort Kh. No.30-37, Village Jindpur Main G.T. Karnal. Road, New Delhi. It was observe that the building is comprised of basement & ground plus one upper floor with covered area of 2569.2m², 2585.43m² & ~~648.16 m²~~. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **Pashupati Nath Resort** Kh. No.30-37, Village Jindpur Main G.T. Karnal. Road, New Delhi.
2. Type of Occupancy : Class-A-1 (i) Residential
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2009/2575 dated 11/08/2009
5. Fire Safety directives letter No. : F6/MS/DFS/BP/2006/1215 dated 26/05/2006
6. Date of inspection : 27.08.2012
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary & Dy. C.F.O (NW)
8. Name and designation of officers
From the building side : Mr. Rohit Gupta
9. Year of Construction :
10. Applicant's letter No. : 42286/Addl. C.P./Lic(H) dated 02/07/12

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtrs	Provided	M.R. ✓
	• Gate width	5 mtr	Provided	M.R. ✓
	• Width of internal road	required	Provided	M.R. ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	6	Provided	M.R. ✓

	<ul style="list-style-type: none"> Basement 	10	Provided	M.R. ✓
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	Old case	Provided	M.R. ✓
	<ul style="list-style-type: none"> Basement 	Old case	Provided	M.R. ✓
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Pressurization 	Required	Provided	M.R. ✓
	d. No. of continuous staircases to terrace	6	Provided	M.R. ✓
	e. Width of Corridor	1.5 mtr	Provided	M.R. ✓
	f. Door size	2 mtr	Provided	M.R. ✓
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Water Curtain 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	M.R. ✓
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R. ✓
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	30	Provided	M.R. ✓

	<ul style="list-style-type: none"> Types 	Required	Provided	M.R.
	<ul style="list-style-type: none"> IS marking 	ISI marks required	provided	M.R.
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	3	Provided	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m required	Provided	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm required	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	M.R.
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	M.R.
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Required	Provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	Provided	M.R.

	<ul style="list-style-type: none"> Number of hydrants per floor 	3	3 Provided	M.R.
	<ul style="list-style-type: none"> Hose Box 	3	Provided	M.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	4	Provided	M.R.
	<ul style="list-style-type: none"> Hose Box 	4	Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	M.R.
	➤ Head of Main pump	60 mtr	Provided	N.R.
	➤ Number of main pumps	2	Provided	M.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	60 mtr	Provided	M.R.
	➤ Standby pump out put	2280 LPM	Provided	M.R.
	➤ Standby pump Head	60 mtr	Provided	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	N.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	30 mtr	Provided	M.R.

	➤ Power supply	Required	N.P	N.M.R.
	➤ Auto Starting of pump	N.A.	N.A.	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1 lak	Provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	N.R.
	➤ Overhead Tank Capacity	10,000	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	No lift	Provided	M.R.
	• Pressurization of Lift lobby	Required	Provided	M.R.
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.

19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chaudhary

Name

Designation

DO (West)

Designation