

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/EH/2012/ 3462

Dated : 21/09/12

FIRE SAFETY CERTIFICATE

Certified that the **Hard Rock Restaurant** located at **M-106 to 117, Multiplex Building, DLF Place, Saket, New Delhi. 110017.** comprised of **Basement, Ground + 3 Upper Floor but the Restaurant is running on 1st Floor only** was granted NOC by this department vide letter No. **F6/DFS/MS/EH/2009/1104** dated **23/04/09**. The premises was re-inspected by the officer concerned of this department on **14/09/12** in the presence of **Anchal Jain** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group – D Assembly Building** with effect from ~~21/09/12~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~21/09/12~~ at New Delhi by.



Chief Fire Officer
Delhi Fire Service

o/c

- Copy to:- (1) Dy. Health Officer,
South Zone, MCD, Green Park, New Delhi.
- (2) Hard Rock Restaurant,
M-106 to 117, Multiplex Building,
DLF Place, Saket, New Delhi. 110017.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Hard Rock Restaurant, M-106 to 117, Multiplex Building, DLF Place, Saket, New Delhi. 110017.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/MS/DFS/EH/2009/1104 dated 23/04/09
5. Fire safety directives No.- No
6. Date of inspection:- 14/09/12.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Anchal Jain.
9. Year of construction:- 2006.
10. Applicant's letter No:- Nil dated 04/09/12 Basement, Ground + 3 Upper Floor but the Restaurant is running on 1st Floor only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	13 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Required	2 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Required 2 mtr.	Provided	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	Required 2 Nos.	Provided	MR
	E. Width of corridor	2 mtr.	2 mtr.	MR
	F. Door size	2 mtr.	2 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust	MR
	2) Upper floors	12 a/c per hour	Yes	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	10 Nos.	MR
	2) Types		ABC	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	1 Nos.	Provided by	MR

			mall	
	2) Length of hose reel hose	30 m	Provided by mall	MR
	3) Nozzle diameter	5 mm	Provided by mall	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	Provided by mall	MR
	2) Number of hydrants per floor	Required	Provided by mall	MR
	3) Hose box	Required	Provided by mall	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided by mall	MR
	2) Hose box	Required	Provided by mall	MR

13.	Pumping Arrangement	Provided & maintained by mall		
	1) Ground level			
	a) Discharge of main pump	-----	-----	-----
	b) Head of main pump	-----	-----	-----
	c) Number of main pump	-----	-----	-----
	d) Jockey pump out put	-----	-----	-----
	e) Jockey pump head	-----	-----	-----
	f) Stand by pump output	-----	-----	-----
	g) Stand by pump head	-----	-----	-----
	h) Auto starting/Manual stopping	-----	-----	-----
	2) Terrace level			
	a) Discharge of pump	-----	-----	-----
	b) Head of pump	-----	-----	-----
	c) Power supply	-----	-----	-----
	d) Auto starting of pump	-----	-----	-----
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	Required	Provided by mall	MR
	a) Draw-off connection	Required	Provided by mall	MR
	b) Fire service inlet	Required	Provided by mall	MR

	c) Access to tank	Required	Provided by mall	MR
	d) Over head tank capacity	Required	Provided by mall	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Provided & maintained by mall		
	a) Detector system panel	-----	-----	-----
	b) Flow switch panel	-----	-----	-----
	c) PA system panel	-----	-----	-----
	d) Battery backup	-----	-----	-----
	e) Building floor plan	-----	-----	-----
20.	Special Fire Protection System for Protection of special Risk, if any:			-----

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:-

Designation:-

Name:- S.S. Kaushik.

Designation:- Assistant Divisional Officer.

Dasgupta

18/9/12

18/9/12