

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/OAS/MS/School/2012/3444

Dated: 20 / 08 / 2012


FIRE SAFETY CERTIFICATE

Certified that the M C Primary School is comprised of Ground + 01 upper floor and three ground floor blocks thus below 09 mtrs, located at Jwala Puri B-1, New Delhi 110087 have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 23/08/2012 in the presence of Principal Sh Yoginder Singh and that the building / premises is fit for occupancy of Group B Educational Building with effect from 20 / 08 / 2012 for a period of three years, subject to conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities no-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

Issued on 20/08/12 at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Principal, M C Primary School, Jwala Puri B-1, New Delhi 110087  
(The school runs for girls in morning shift and for boys in evening shift with ID-1757014 and ID-1757015)
2. The Director of Education, ~~Old Secretariat~~, Delhi  
ncd Civic Centre

INSPECTION REPORT

1. Name & address of the building: MCP School Jwala Puri - B-1  
New Delhi - 110087 D 1757014
2. Type of Occupancy: School ID 1757015
3. Type of Case: Now
4. Details of previous NOC: Letter No NIL
5. Fire Safety directives Letter No.: Dir of Edu
6. Date of inspection: 23/8/12
7. Name of the Inspecting Officer: ADSS Tuli
8. Name and designation of Officer: Sh. Yoginder Singh  
from the building side
9. Year of Construction: 2002
10. Applicant's letter No.: 16/7/12

Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
<u>Access of building</u>			
• Road width	<u>Accessible</u>		<u>M/R</u>
• Gate width	<u>6 mtr</u>	<u>6 mtr</u>	<u>M/R</u>
• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
<u>Number, width, Type &amp; Arrangements of exits</u>			
a. Number of staircases	<u>Two</u>	<u>P</u>	<u>M/R</u>
• Upper floors	<u>yes</u>	<u>P</u>	<u>M/R</u>
• Basements	<u>—</u>	<u>—</u>	<u>—</u>
b. Width of staircases	<u>1.5 mtr or greater</u>		
• Upper floors	<u>of less than 1.5m</u>	<u>(P) 130cms</u> <u>125cms</u>	<u>M/R</u>
• Basements	<u>—</u>	<u>—</u>	<u>—</u>
c. Protection of exits	<u>—</u>		
• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
d. No of continuous staircase to terrace	<u>—</u>	<u>—</u>	<u>—</u>



	e. Width Of Corridor	N/A	NP	N/A
	f. Door Size	1 mtr	1 mtr	N/A
3.	Compartmentation	N/A	N/A	N/A
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke managements System	N/A	NP	NA
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5.	Fire Extinguishers			
	• Total numbers	one @ 300 m <sup>2</sup>	08 ABC	N/A
	• Types		yes	yes
	• IS marking	ISI marked	yes	yes
6.	First - Aid Hose Reels	N/A	yes	yes
	• Total numbers on each floor	—	NP	NP
	• Length of hose reel hose	—	—	—
	• Nozzle diameter	—	—	—
7.	Automatic fire detection and alarming system	N/A	NP	NA
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8.	MOEFA	N/A	NP	NA
9.	Public Address System	—	—	—
10.	Automatic Sprinkler System	—	—	—
	• Basements	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants	—	—	—
	• Size of riser/down-comer	—	—	—

	• Number of hydrants per floor	NR	NP	NA
	• Hose Box	-	-	-
	Yard Hydrants	-	-	-
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements	NR	NP	NA
	• Ground Level	-	-	-
	• Discharge of main pump	-	-	-
	➤ Head of main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
	• Pump House Access	-	-	-
	• Terrace level	-	-	-
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power supply	-	-	-
	➤ Auto starting of pump	-	-	-
4.	Captive water Storage for fire fighting	NR	NP	NA
	• Under ground tank capacity	-	-	-
	➤ Draw of connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-
5	Exit Signage	-	-	-
5.	Provision of Lifts.	NR	NP	NA
	➤ Pressurization of Lift Shaft	-	-	-
	➤ Pressurization of lift lobby	-	-	-
	➤ Communication in lift Car	-	-	-

		NR	NP	NP
	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>			
17.	Standby power supply	—	—	—
18.	Refuge Area	—	—	—
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	—	—	—
19.	Fire control room	—	—	—
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>	—	—	—
20.	Special Fire Protection Systems for Protection of special Risks, if any;	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings~~ as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation

20 (M/W)  
24-8-12

Signature of the Inspecting Officer

Name

Designation

23/8/12  
S.S. Tuli  
AIO(M/W)