

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO.F6/DFS/MS/GH/2012/ 3539

Dated: 25/09/12

FIRE SAFETY CERTIFICATE

Certified that the **M/s Ashoka Guest House** located at **1969-71, Katra Lachoo Singh, Fountain, Chandni Chowk, Delhi** comprised of ground floor (Reception + commercial use for other party), 1st floor (11 guest rooms), 2nd floor (11 guest rooms), 3rd floor (11 guest rooms) and fourth floor (01 store + 01 staff room + 01 generator room) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/1970 dated 06-07-2009. The premises was re-inspected by the officer concerned of this department on 19-09-2012 in the presence of Amarjeet Kumar, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class Residential Building (Lodging houses) with effect from 25/09/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 25/09/12 at New Delhi by.



**Chief Fire Officer
Delhi fire service**

92 10

Copy to: -

1. The Additional Commissioner of Police (Licensing), Police Station, Defence Colony, 1st Floor, New Delhi w.r.t letter No. 48909-10/Addl.C.P/Lic(H) dated 07-08-2012
2. The Manager, M/s Ashoka Guest House, 1969-71 Katra Lachoo Singh Fountain, Chandni Chowk, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

3.	Compartmentation.	Not required	N/A	-
	• Fire check door	N/A	N/A	-----
	• Sealing of electrical shafts	N/A	N/A	-----
	• Fire Rating of shaft door	N/A	N/A	-----
	• Water Curtain	N/A	N/A	-----
	• Fire Dampers	N/A	N/A	-----
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers 12	water CO ₂ - 6	provided	MR
	• Types water CO ₂ , CO ₂	CO ₂ - 6	provided	MR
	• IS marking	ISI marked	provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	1	provided	MR
	• Length of hose reel hose	30 m	provided	MR
	• Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	-----
	• Location of Main Panel	N/A	N/A	-----
	• Location of Repeater Panel	N/A	N/A	-----
	• Alternate source of power	N/A	N/A	-----
	• Hooters' Location	N/A	N/A	-----
8	MOEFA	N/A	N/A	-
9	Public Address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	-----
	• Upper Floor	N/A	N/A	-----
	• Sprinkler above false ceiling	N/A	N/A	-----

g

11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	-----
	• Number of hydrants per floor	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	-----
	➤ Discharge of main Pump	N/A	N/A	-----
	➤ Head of Main pump	N/A	N/A	-----
	➤ Number of main pumps	N/A	N/A	-----
	➤ Jockey Pump out put	N/A	N/A	-----
	➤ Jockey pump head	N/A	N/A	-----
	➤ Standby Pump out put	N/A	N/A	-----
	➤ Standby Pump Head	N/A	N/A	-----
	➤ Auto Starting/ Manual stopping	N/A	N/A	-----
	➤ Pump House Access	N/A	N/A	-----
	• Terrace level	-	-	-
	➤ Discharge of pump	275 LPM	275 LPM	MR ✓
	➤ Head of the pump	25 mtr	25 mtr	MR ✓
	➤ Power Supply	Required	provided	MR
	➤ Auto Starting of pump	-	provided near GF reception	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	-----
	➤ Draw-off connection	N/A	N/A	-----
	➤ Fire service inlet	N/A	N/A	-----
	➤ Access to tank	N/A	N/A	-----
	• Overhead Tank capacity	2500 lb.	2500 lb	MR
15	Exit Signage.	Required	Provided	MR

lp

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	-----
	• Pressurization of Lift lobby	N/A	N/A	-----
	• Communication In lift Car	N/A	N/A	-----
	• Fireman's Grounding Switch	N/A	N/A	-----
	• Lift Signage	N/A	N/A	-----
17	Standby power supply	Required	provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ type fire extinguisher provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to /grant/ renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation :- Assistant Divisional Officer

DO (CD)

Submitted please.

By CFO (CNDZ)

21/01/12