

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DPS/MS/EH/2012/3530

Dated: 25/09/12

FIRE SAFETY CERTIFICATE

Certified that the BARBEQUE NATION RESTAURANT at G -2 & G -3 Ginger Hotel, Plot No.C,DDA Community Centre, Vivek Vihar,Delhi,owned/occupied by M/S Barbeque Nation Hospitality Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 17.09.12 in the presence of Sh.R.P.Chaudhary owner of restaurant, that the building (Ground floor) is fit for occupancy Group – D 'Assembly building' (Restaurant) with effect from ..25/09/12.. for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....25/09/12.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

JK
25/9/12

To,
The Dy. Health Officer
East Delhi Municipal Corporation
Health Department, Karkardooma
South Zone, Shahdara, Delhi.

Copy to:-
M/S Barbeque Nation Restaurant
G -2 & G -3 Ginger Hotel, Plot No.C,
DDA Community Centre, Vivek Vihar,
Delhi.

Recd
A
my

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Barbeque Nation at G-2 & G -3 Ginger Hotel, Plot No.C,DDA
Community Centre,Vivek Vihar,Delhi.
2. Type of Occupancy : Assembly at ground floor.(Restaurant)
3. Type of Case : New
4. Details of Previous NOC : F.6/DFS/MS/Hotel/2010/2247 dated 29.07.12 for Ginger Hotel.
5. Fire Safety directives No : NBC
6. Date of Inspection : 17.09.12
7. Name of the Inspecting Officer : ADO Suresh Singh & DO Virendra Singh
8. Name of the designation of Officer
From the building side : Sh.P.R.Chaudhary
9. Year of Construction : 2009
- 10.Applicant's letter No : 21.0.12 &12.09.12

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs	30 Mtrs.	MR
		4.5 Mtrs.	6 Mtrs.	MR
		-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	-----	-----	-----
	• Upper Floor	-----	-----	-----
	• Basement	-----	-----	-----
	B. Width of Staircases	-----	-----	-----
	• Upper Floor	-----	-----	-----
	• Basement	-----	-----	-----
	c. Protection of exits	-----	-----	-----
	• Fire check door	Required	Provided	MR
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	-----	-----	-----
	g. Width of Corridor	-----	-----	-----
	h. Door Size	2.0 Mtrs.	3 nos. 2.0 Mtrs. each	MR
3	Compartmentation.	Required	Provided for entire building	
	• Fire check door	-----	Provided	MR
	• Sealing of electrical shafts	-----	Sealed	MR
	• Fire rating of shaft door	-----	-----	-----
	• Water curtain	-----	-----	-----
	• Fire Dampers	-----	-----	-----
4	Smoke Management System.			
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5.	Fire Extinguisher			
	• Total numbers	4 Nos.	06 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter 	1 no.	Provided	MR ✓
		30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power 	Heat & smoke	Provided	MR
		-----	At ground floor	MR
		-----	-----	-----
		Battery & DG Set	Provided	MR
	<ul style="list-style-type: none"> Hooters's location 	Different Location	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.	-----	Provided	MR
	<ul style="list-style-type: none"> basement upper floor sprinkler above false ceiling 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	150 mm	MR ✓
		1no.	1 no.	MR
		1 no.	1 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Not Required	1no.	MR
		Not Required	1 no.	MR
13	Pumping Arrangements.	For main	building	
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access 	-----	Provided	MR
		-----	2280 LPM	MR
		-----	88 mtrs	MR
		-----	2 nos.	MR
		-----	450 LPM	MR
		-----	88 mtrs.	MR
		-----	2280 LPM	MR
		-----	88 Mtrs.	MR
		-----	Provided	MR
		-----	Provided	MR
	<ul style="list-style-type: none"> Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 			
		450 LPM	Provided	MR
		88 mtrs.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	For main	building	
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection 	-----	2,00,000 Ltrs.	MR
		-----	Provided	MR

	➤ Fire service inlet	-----	Provided	MR
	➤ Access to tank	-----	Provided	MR
	• Overhead Tank capacity	20000 Ltrs.	20000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	For main	building	
	• Detector system panel	-----	Provided	MR
	• Flow switch panel	-----	----do----	MR
	• PA system panel	-----	----do----	MR
	• Batter backup	-----	----do---	MR
	• Building Floor Plans	-----	----do---	MR
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
19.9.12
Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*

Vingh
Signature of the Inspecting Officer
Name *VIRENDRA SINGH*
DIVISIONAL OFFICER
Designation *A*