

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.


No. *FG/DFS/ms/Hospital/2012/3519*

Dated: *25/09/12*

FIRE SAFETY CERTIFICATE

Certified that the **Bhagat Chandra Hospital** located at RZF-1/1, Mahavir Enclave, New Delhi-110045. The hospital building having three blocks namely A, B & C. Block A comprised of basement, ground plus two upper floors, Block B comprised of basement, ground plus one upper floor and Block C comprised of ground plus two upper floors. All three blocks are interconnected at first floor, using basement as O.P.D, Blood Bank, Store & Medical Record, ground floor used as reception, O.P.D, I.C.U, Cath Lab, O.T & office, the first floor used as children ward, general ward, private room, office & I.B.F. Second floor is sealed by the owner owned/ occupied by the management of Bhagat Chandra Hospital have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 29.08.2012 in the presence of Sh. Gavaskar Nayak (Electrician) & Sh. Pardeep Kumar and that the building / premises is fit for occupancy class- Group-C institutional building Sub. Div. C-1 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on *25/09/12*at New Delhi.




CHIEF FIRE OFFICER
DELHI FIRE SERVICE

*ok
me*

Copy to:-

1. Sh. C.M. Bhagat (Director),
Bhagat Chandra Hospital,
RZF-1/1, Mahavir Enclave,
New Delhi-110045.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The position of the staircases shall not be changed with out the permission of the competent authority.
8. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

M/9

Basement, Ground plus One Upper Floor

INSPECTION REPORT

1. Name & address of the building: Bhagat Chandra Hospital, RZF-111, Mahavir Enclave, Group C (Institutional Subdiv. C-1) M.D-45.
2. Type of Occupancy: New Case/Renewal
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. N/A Date
5. Fire Safety directives letter No: N/A
6. Date of inspection: 29.08.2012
7. Name of Inspecting Officer: D.O H.C. Aneja & A.D.O P.S. Dahiya
8. Name and designation of officers: Sh. Gavaskar Nayak, Sh. Pardeep Kumar
9. Year of Construction: 1997
10. Applicant's letter No: Nil dated 28.06.2012

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/BBL | Provided at | Remarks |
|--------|---|-----------------|---|---------|
| | | Requirement | site | |
| 1. | Access to building | | | MR/NMR |
| | • Road width | Accessible | 18mtr | MR |
| | • Gate width | - | 510cm, 440cm, 370cm, 300cm | MR |
| | • Width of internal road / Side Road | - | 06mtr | MR |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | Nine | Nine | MR |
| | • Basements | - | Five | MR |
| | b. Width of staircases | | | |
| | • Upper Floor | 200cm | 200, 200, 175, 175, 150, 135, 145, 194, 120cm | MR |
| | • Basements | - | 133, 128, 118, 120, 125cm | MR |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • pressurization | N/A | - | - |
| | d. No. of continuous staircases to terrace | - | Three | - |
| | e. Width of Corridor | - | 175cm, 155cm | - |
| | f. Door Size | - | 95cm x 210cm | - |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | - | - |
| | • Sealing of electrical shafts | - | Sealed | - |
| | • Fire Rating of shaft door | N/A | - | - |
| | • Water Curtain | N/A | - | - |
| | • Fire Dampers | N/A | - | - |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | Exhaust Fan are Provided | MR |
| | • Upper floors | | Natural Ventilation | MR |

N/A

| | | | | |
|-----|--|--|------------------------------------|----|
| | | 12 a/c per hour | - | - |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | Ten at each Floor | Provided | MR |
| | • Types | CO ₂ , WCO ₂ , A.B.C | - do - | MR |
| | • IS marking | ISI marked | ISI marked | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | Four | Provided | MR |
| | • Length of hose reel hose | 30 m | - do - | MR |
| | • Nozzle diameter | 5 mm | - do - | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | - | Smoke | MR |
| | • Location of Main Panel | - | At Reception | MR |
| | • Location of Repeater Panel | - | - do - | MR |
| | • Alternate source of power | - | Two D.G. Set of 125kva, 200 kVA | MR |
| | • Hooters' Location | - | In Staircase | MR |
| 8. | MOEFA | | | |
| | | Required | Provided | MR |
| 9. | Public Address System | | | |
| | | - do - | - do - | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | Required | Provided | MR |
| | • Upper Floor | N/A | - | - |
| | • Sprinkler above false ceiling | N/A | - | - |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100 m.m | 100 m.m | MR |
| | • Number of hydrants per floor | - | Four | MR |
| | • Hose Box | - | Two | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | - | Three | MR |
| | • Hose Box | - | - do - | MR |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | - | - |
| | ➤ Head of Main pump | N/A | - | - |
| | ➤ Number of main pumps | N/A | - | - |
| | ➤ Jockey Pump out put | N/A | - | - |
| | ➤ Jockey pump head | N/A | - | - |
| | ➤ Standby Pump out put | N/A | - | - |
| | ➤ Standby Pump Head | N/A | - | - |
| | ➤ Auto Starting/Manual stopping | N/A | - | - |
| | | N/A | - | - |

N/11

RZF-1/1, Mahavir Enclave,
New Delhi - 110045.


| | | | | |
|-----|---|-----------------|----------------------|----------|
| | <ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | N/A | - | - |
| | | 900 LPM | 900 LPM, 180 LPM | MR |
| | | 30M Required | 44M, 46M Provided | MR MR |
| | | - | - | - |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | N/R | 50000 Ltr | - |
| | | N/R | - | - |
| | | N/A | Provided | MR |
| | | - | - do - | MR |
| | | 10000 Ltr | 10000 Ltr | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N/A | - | - |
| | | N/A | - | - |
| | | - | Provided | MR |
| | | Required | - do - | MR |
| | | - do - | - do - | MR |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | N/A | - | - |
| | | N/A | - | - |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | N/A | - | - |
| | | N/A | - | - |
| | | N/A | - | - |
| | | Required | Provided | MR |
| | | N/A | - | - |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | - | - |

N/12

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The Hospital building having three blocks namely A, B & C. Block A comprised of Basement, Ground + 02 upper floors, Block B & C comprised of Basement, G.F + 01 upper floor. All three blocks are interconnected at first floor. The basement used as O.P.D, Blood Bank, Store & medical records, the ground floor used as O.P.D, Reception, I.C.U, Cath Lab, O.T, Lab, Office, the first floor as used as Children ward, General ward, Private room, Office, I.B.F. The owner of the hospital submitted an affidavit that the second floor of the building is sealed.


Signature of Inspecting Officer

Name H.L. Anuja

Designation Divisional Officer


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.