

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DF5/MS/EH/2012/3522

Dated: 25/09/12

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s. Haze (a unit of Shri Sai Entertainments)** at SF-22-01 to SF-22-06 Second Floor, West Gate Mall, Raja Garden, New Delhi, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 14.09.12 in presence of **Sh. Ashok Nandra** of the Restaurant and that the premises is fit for **Class-D (Assembly)** occupancy with effect from... 25/09/12... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and a subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..... 25/09/12 ..... at New Delhi by

  
25/9  
Chief Fire Officer  
Delhi Fire Service



Copy to:

1. Dy. Health Officer  
Municipal Corporation of Delhi  
West Zone, Rajouri Garden, New Delhi-110027.
2. Sh. Ashok Nandra  
M/s Haze ( a unit of Shri Sai Entertainments)  
SF-22-01 to SF-22-06 Second Floor, West Gate Mall, Raja Garden, New Delhi

Note: - for general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : M/s Haze (a unit of Shri Sai Entertainments) at SF-22-01 to SF-22-06 Second floor, West Gate Mall, Raja Garden, New Delhi.
2. Type of Occupancy : Class-D (Assembly) *Restaurant.*
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 14.09.2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
- From the building side : Sh. Ashok Nandra
- Year of Construction : Old Construction
9. Applicant's letter No. : D-1636/HD/WZ dated 12.09.12

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12 mtrs	More than 20 mtr ✓	M/R
	• Gate width	45 mtr	Provided ✓	M/R
	• Width of internal road	Required	Provided	M.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	3 ✓	M.R.
	• Basement	Not for Restaurant	Not for Restaurant ✓	Not for Restaurant
	b. Width of staircases			

	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basement</li> </ul>	1.5mtr.	1.5 mtr. ✓	M.R/Being renewal case
		Required for Mall	Provided ✓	M.R.
	c. Protection of exits			
		<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided ✓
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	Required	Provided ✓	M.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	2 mtr	Provided ✓	M.R.
	f. Door size	1.5 mtr	1.65 mtr & 1.50 mtr ✓	M.R.
3.	<b>Compartmentation.</b>			
		<b>For the Mall</b>		
<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required	Provided ✓	M.R.	
	Required	Provided ✓	M.R.	
	Required	Provided ✓	M.R.	
	N/R	N/A	N.R.	
	Required	Provided ✓	M.R.	
4.	<b>Smoke Management System.</b>			
<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	Required	Provided ✓	M.R.	
	N.R. Required for Restaurant	Provided ✓	M.R.	
5.	<b>Fire Extinguishers</b>			
<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	06	08	M.R.	
	ABC & CO <sub>2</sub>	provided ✓	M.R.	
	ISI marks	provided ✓	M.R.	

6.	<b>First-Aid Hose Rees.</b>			
	• Total numbers on each floor	3	Provided ✓	M.R
	• Length of hose reel hose	30 m required	provided ✓	M.R
	• Nozzle diameter	5 mm required	provided ✓	M.R
7.	<b>Automatic fire detection and alarming system.</b>			
			<b>Common with Mall</b>	
	• Type of detectors	Smoke Heat	Provided ✓	M.R
	• Location of Main Panel	G. Floor	provided ✓	M.R
	• Location of Repeater Panel	On each floor	provided ✓	M.R
	• Alternate source of power	Required	provided ✓	M.R
	• Hooter's Location	Required	Provided ✓	M.R
8.	<b>MOEFA</b>	Required	Provided ✓	M.R
9.	<b>Public Address System</b>	Required	Provided ✓	M.R.
10.	<b>Automatic Sprinkler system</b>			
	• Basement	Required	Provided ✓	M.R.
	• Upper Floor	Required	Provided ✓	M.R
	• Sprinkler above false ceiling	Required for the Restaurant	Provided ✓	M.R
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	provided ✓	M.R
	• Number of hydrants per floor	3	Provided ✓	M.R
	• Hose Box	3	Provided ✓	M.R

<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/R For restaurant	4 Provided in the mall	✓ M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/R For restaurant	Provided in the mall	✓ M.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2280 LPM Of the Mall	Provided (common with the mall)	✓ M/R
	➤ Head of Main pump	60 mtr	Provided	M/R
	➤ Number of main pumps	2	Provided	✓ M/R
	➤ Jockey Pump out put	180 LPM	Provided(common with the mall)	✓ M.R.
	➤ Jockey pump head	40 mtr	Provided	M.R.
	➤ Standby pump out put	2280 LPM Of the Mall	Provided (common with mall)	✓ M/R
	➤ Standby pump Head	60 mtr	Provided	M/R
	➤ Auto Starting/Manual stopping	Required	Provided	✓ M/R
	➤ Pump Hose Access	Required	Provided	✓ M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided (common with mall)	✓ M.R.
	➤ Head of the pump	40 mtr	Provided	✓ M.R.
	➤ Power supply	Required	Provided	✓ M.R.
	➤ Auto Starting of pump	Required	Provided	✓ M.R.

<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	50,000 ltrs	Provided (common with mall) ✓	M.R.
	➤ Draw -off connection	Required	Provided ✓	M.R.
	➤ Fire service inlet	Required	Provided ✓	M.R.
	➤ Access to tank	Required	Provided ✓	M.R.
	➤ Overhead Tank Capacity	10, 000 ltrs	Provided (common with mall)	M.R.
<b>15</b>	<b>Exit Signage.</b>	Required	Provided ✓	M.R.
<b>16.</b>	<b>Provision of Lifts</b>	For Mall	For Mall ✓	
	• Pressurization of Lift Shaft	Required	Provided ✓	M.R.
	• Pressurization of Lift lobby	Required	Provided ✓	M.R.
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided ✓	M.R.
	• Lift Signage	Required	Provided ✓	M.R.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided (common with mall) ✓	M.R.
<b>18.</b>	<b>Refuge Area</b>	N.R.	N.R.	N.R.
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.R.	N.R.	N.R.

	➤ Flow Switch Panel	N.R.	N.R.	N.R
	➤ PA system Panel	N.R.	N.R.	N.R
	➤ Batter backup	N.R.	N.R.	N.R
	➤ Building Floor plans	N.R.	N.R.	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the  Inspection Officer

Signature of the Inspection Officer

Name

*Gurish Chaudhary*

Name

Designation

*D.O. West*

Designation