

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001


No: F.6/DFS/MS/2012/ *school/3586*

Dated: *28/09/12*

FIRE SAFETY CERTIFICATE

Certified that the – **M.C. Primary School, C-4-E, Janak Puri**, New Delhi-110058 Comprised of - ground floor plus one upper floor, owned/occupied by Director of Education M.C.D has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire Service on 29.08.12 in the presence of Sh.. Dayanand Rohilla Principal and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on ...*28/09/12*.....at New Delhi.


Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal,
M.C. Primary School,
C-4--E, Janak Puri
New Delhi-110058.
2. The Director of Education
MCD Nigam Bhawan (Old Hindu Collage Bldg)
Kashmere Gate, Delhi.
3. Divisional Officer (South West)
Shanker Road Fire Station, New Delhi

ok
mev

Note * :- For general fire safety directives please see overleaf

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the responsibility of the management.
3. The staff should be trained available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.

C-11

INSPECTION REPORT

- 1. Name & address of the building : M.C Primary School, C-4-E, Jangke Puri NO
- 2. Type of Occupancy : & educational
- 3. Type of Case : New Case/ Renewal
- 4. Details of previous NOC : Letter No. NIL Dated: —
- 5. Fire Safety directives letter No : NIL
- 6. Date of inspection : 29/8/12
- 7. Name of the Inspecting Officers : D.O. H.C. ANEJA
- 8. Name and designation of officers from the building side : —
- 9. Year of Construction : —
- 10. Applicant's letter No. : Sh Daya Nand Rohilla Principal.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	9mtrs	MR
	• Gate width	R	4.10 mtrs	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	TWO	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	b. Width of staircases	R	150, 150 Cms each	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	TWO	MR
	g. Width of Corridor	R	2.16 mtrs	MR
	h. Door Size	R	112 cms	MR

3	Compartmentation.					
	• Fire check door	NR				
	• Sealing of electrical shafts					
	• Fire Rating of shaft door					
	• Water Curtain					
	• Fire Dampers					
4	Smoke Management System.	NR				
	• Basements	30 a/c per hour				
	• Upper floors	12 a/c per hour				
5	Fire Extinguishers	R	P			NR
	• Total numbers					NR
	• Types					NR
	• IS marking	ISI marked	2 CO2 type 4 DEP Jm Yes			u
6	First-Aid Hose Reels.	NR				
	• Total numbers on each floor					
	• Length of hose reel hose	30 m				
	• Nozzle diameter	5 mm				
7	Automatic fire detection and alarming system.	NR				
	• Type of detectors					
	• Location of Main Panel					
	• Location of Repeater Panel					
	• Alternate source of power					
	• Hooters' Location					
8	MOEFA					
9	Public Address System.	NR				
10	Automatic Sprinkler System.					
	• Basement	NR				
		ALL				

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	NR		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	—
12	Yard Hydrants.	NR		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—
13	Pumping Arrangements.	NR		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.	NR		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	NR	—	—
16	Provision of Lifts.	NR	—	—
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17	Standby power supply	NR	—	—
18	Refuge Area.	NR	—	—
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19	Fire Control Room	NR	—	—
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ NIL

Handwritten signature

Signature of the Inspecting Officer

Name *H. L. ANEJA*

Designation *Div. Officer*

Signature of the Inspecting Officer

Name

Designation

Handwritten signature