

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/2012/3671

Dated: 05/10/2012

FIRE SAFETY CERTIFICATE

Certified that the **Barbeque Nation Restaurant** (A unit of Barbeque Nation Hospitality Ltd.) located at Unit no. 101 and 102, first floor, A-7 Netaji Subhash Place, Pitampura, New Delhi, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 20.09.12 in the presence of Sh. Manoj of the Restaurant and that the premises is fit for **Class-D (Assembly)** occupancy with effect from05/10/12..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....05/10/12.....at New Delhi by


Chief Fire Officer
Delhi Fire Service

8/12


Copy to:

1. Barbeque Nation Restaurant (A unit of Barbeque Nation Hospitality Ltd)
Unit no. 101 and 102 first floor A-7 Netaji Subhash Place, Pitampura, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs. delhigovt. nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no.nil dated 17/08/2012 received from the authrosied Signatory regarding of NOC in r/o Barbeque Nation Restaurant (A unit of Barbeque Nation Hospitality Ltd.) located at Unit no. 101 and 102 first floor A-7 Netaji Subhash Place, Pitampura, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : Barbeque Nation Restaurant (A unit of Barbeque Nation Hospitality Ltd.) located at Unit no. 101 and 102 first floor A-7 Netaji Subhash Place, Pitampura, New Delhi
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 20.09.2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
 From the building side : Sh. Manoj
 Year of Construction :
9. Applicant's letter No. : nil dated 17.08.12

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
		of the mall	of the mall	
	• Road width	12 mtrs	50 mtr	M/R ✓
	• Gate width	5 mtr	Provided	M/R ✓
	• Width of internal road	06 mtr	Provided	M.R. ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2 for restaurant	3 for restaurant	M.R. ✓

	<ul style="list-style-type: none"> • Upper Floors • Basement 	2	Provided	M.R.
		N.A.	N.A.	N.A.
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	2 staircase of 1.5 mtr width each	1.5 mtr, 1.25 mtr & 2 mtr for restaurant	M.R.
		N.A.	N.A.	N.A.
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required	Provided	M.R.
		Required	Provided	M.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	2 mtr for Restaurant	Provided	M.R.
f. Door size	2 doors 1.5 mtr each	2= (2 mtr), 4=(1.25 mtr)	M.R.	
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	M.R.
		Required	Provided	M.R.
		Required	Provided	M.R.
		N.A.	N.A.	N.A.
		required	Provided	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N.A.	N.A.	N.A.
		Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	10 For the restaurant	10	M.R.


	<ul style="list-style-type: none"> Types IS marking 	ABC & CO ₂	provided	M.R ✓
		ISI marks	provided	M.R ✓
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	1 required	Provided	M.R ✓
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m required	provided	M.R ✓
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm required	provided	M.R ✓
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat for restaurant	Provided	M.R ✓
	<ul style="list-style-type: none"> Location of Main Panel 	First floor at restaurant level	provided	M.R ✓
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.A.	N.A.	N.A. ✓
	<ul style="list-style-type: none"> Alternate source of power 	Required	provided	M.R ✓
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R ✓
8.	MOEFA	Required for Restaurant	Provided	M.R ✓
9.	Public Address System	Not Required	Provided	M.R ✓
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	N.A. ✓
	<ul style="list-style-type: none"> Upper Floor 	Required for the restaurant	Provided	M.R ✓
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required for the Restaurant	Provided	M.R ✓
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	provided	M.R ✓

	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	M.R. ✓
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	M.R. ✓
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N.A.	N.A.	N.A. ✓
	<ul style="list-style-type: none"> • Hose Box 	N.A.	N.A.	N.A. ✓
13.	Pumping Arrangements.			
	Ground Level	Common for building		
	➤ Discharge of main pump	2280 LPM	Provided	M/R ✓
	➤ Head of Main pump	90 mtr	Provided	M/R ✓
	➤ Number of main pumps	2 electric	Provided	M/R ✓
	➤ Jockey Pump out put	180 LPM	Provided	M.R. ✓
	➤ Jockey pump head	90 mtr	Provided	M.R. ✓
	➤ Standby pump out put	2280 LPM Diesel	Provided	M/R ✓
	➤ Standby pump Head	90 mtr	Provided	M/R ✓
	➤ Auto Starting/Manual stopping	Required	Provided	M/R ✓
	➤ Pump Hose Access	Required	Provided	M.R. ✓
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R. ✓
	➤ Head of the pump	50 mtr	Provided	M.R. ✓

	➤ Power supply	Required	Provided	M.R ✓
	➤ Auto Starting of pump	Required	Provided	M.R ✓
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N.A.	N.A.	N.A. ✓
	➤ Draw -off connection	N.A.	N.A.	N.A. ✓
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A. ✓
	➤ Overhead Tank Capacity	20, 000 ltrs	Provided	M.R ✓
15	Exit Signage.	Required	Provided	M.R ✓
16.	Provision of Lifts	For building	For building	
	• Pressurization of Lift Shaft	Required	Provided	M.R. ✓
	• Pressurization of Lift lobby	Required	Provided	M.R. ✓
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided	M.R. ✓
	• Lift Signage	Required	Provided	M.R. ✓
17.	Standby power supply	Required	Provided	M.R ✓
18.	Refuge Area	N.R.	N.R	N.R
	➤ Total Area	N.A.	N.A.	N.A. ✓
	➤ Location	N.A.	N.A.	N.A. ✓

19.	Fire Control Room			
	➤ Detector System Panel	N.A.	N.A.	N.A. ✓
	➤ Flow Switch Panel	N.A.	N.A.	N.A. ✓
	➤ PA system Panel	N.A.	N.A.	N.A. ✓
	➤ Batter backup	N.A.	N.A.	N.A.
	➤ Building Floor plans	N.A.	N.A.	N.A. ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A. ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.


Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chaudhary

Name

Designation D.O (west),

Designation

DY CFB

keentat
28/9/12