

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 3620

Dated: 03/10/12

FIRE SAFETY CERTIFICATE

Certified that M/s Rest Inn, located at 3938, Urdu Bazar, Jama Masjid, Delhi comprised of ground floor (Commercial use), first (Reception + 11guest rooms + office), second (13 guest rooms) & third floor (02 staff rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/2726 dated 07-09-2009. The premises was re-inspected by the officer concerned of this department on 20-09-2012 in the presence of Jamil Ahmed, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from - ~~03/10/12~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~03/10/12~~ at New Delhi by.



Chief Fire Officer
Delhi fire service

9c 12

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, Rest Inn, 3938, Urdu Bazar, Jama Masjid, Delhi.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

2/n

Old Case

INSPECTION REPORT

1. Name & address of the building : Rest Inn, 3938, Urdu Bazar, Jama Masjid, Delhi
2. Type of Occupancy : Lodging House / Eating House / Club
3. Type of Case : Renewal / New case
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : FG/DF/MS/GH/09/2726 dated 07/09/2009
6. Date of inspection : 20/9/2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
8. Name and designation of officers from the building side : Jamil Ahmed, Manager
9. Year of Construction : 1958
10. Applicant's letter No. : 39756/Addl.C.P/Lic(H) dated 20/8/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Spl area	30mt	MR
	• Gate width	-	Directly accessible from the main road	MR
	• Width of internal road	N/A	N/A	-----
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	-----
	b. Width of staircases	-	-	-
	• Upper Floors	0.80 mt.	1.07mt, 1.0 mt	MR
	• Basements	N/A	N/A	-----
	c. Protection of exits	N/A	N/A	-----
	• Fire check door	N/A	N/A	-----
	• Pressurization	N/A	N/A	-----
	e. No. of continuous staircases to terrace	02	02	MR
	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	N/A	N/A	-----
		N/A	N/A	-----

GF - Commercial use.

1st floor - 11 G. rooms + reception + office.

2nd floor - 13 G. rooms.

3rd floor - 02 staff rooms.

J

3	Compartmentation.	Not required		
	• Fire check door	N/A	N/A	-----
	• Sealing of electrical shafts	N/A	N/A	-----
	• Fire Rating of shaft door	N/A	N/A	-----
	• Water Curtain	N/A	N/A	-----
	• Fire Dampers	N/A	N/A	-----
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers 06	water CO ₂ - 4	provided	MR ✓
	• Types water CO ₂ , CO ₂	CO ₂ - 2	provided	MR
	• IS marking	ISI marked	provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	provided	MR ✓
	• Length of hose reel hose	30 m	provided	MR
	• Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	-----
	• Location of Main Panel	N/A	N/A	-----
	• Location of Repeater Panel	N/A	N/A	-----
	• Alternate source of power	N/A	N/A	-----
	• Hooters' Location	N/A	N/A	-----
8	MOEFA	NA	NA	-
9	Public Address System.	NA	NA	-
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	-----
	• Upper Floor	N/A	N/A	-----
	• Sprinkler above false ceiling	N/A	N/A	-----

9/W

11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	-----
	• Number of hydrants per floor	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	-----
	➤ Discharge of main Pump	N/A	N/A	-----
	➤ Head of Main pump	N/A	N/A	-----
	➤ Number of main pumps	N/A	N/A	-----
	➤ Jockey Pump out put	N/A	N/A	-----
	➤ Jockey pump head	N/A	N/A	-----
	➤ Standby Pump out put	N/A	N/A	-----
	➤ Standby Pump Head	N/A	N/A	-----
	➤ Auto Starting/ Manual stopping	N/A	N/A	-----
	➤ Pump House Access	N/A	N/A	-----
	• Terrace level			
	➤ Discharge of pump	225 LPM	provided	MR ✓
	➤ Head of the pump	25 mt	provided	MR
	➤ Power Supply	Required	provided	MR
	➤ Auto Starting of pump	-	starting switch provided near reception	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	-----
	➤ Draw-off connection	N/A	N/A	-----
	➤ Fire service inlet	N/A	N/A	-----
	➤ Access to tank	N/A	N/A	-----
	• Overhead Tank capacity	2500 ltr	3000 ltr.	MR ✓
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	-----
	• Pressurization of Lift lobby	N/A	N/A	-----
	• Communication In lift Car	N/A	N/A	-----
	• Fireman's Grounding Switch	N/A	N/A	-----
	• Lift Signage	N/A	N/A	-----
17	Standby power supply	Required	7.5 KVA	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ type fire extinguisher found provided near Elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation :- Assistant Divisional Officer

DO (CD)

Submitted please.

By CFO (ND2)

Vijay
26/01/12

Sua