

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2012/ 3746

Dated: 10/10/12

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Girls School, Hari Nagar Ashram, New Delhi**, comprised of ground plus one upper floor **Owned/Occupied** by M.C. Primary Girls School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 03.09.2012 in the presence of Mrs. Sushila Monika Ekka, Principal of the school and that the building / premises is fit for occupancy class-B "Educational building" with effect from 10/10/12 for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 10/10/12 at New Delhi by



**CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy To: -

1. The Directorate of Education, South MCD Civic Centre. 9th Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. The Principal, MC Primary Girls School, Hari Nagar Ashram, New Delhi-14

Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building : M.C. PRIMARY GIRLS SCHOOL,
HARI NAGAR ASHRAM,
NEW DELHI - 110014
2. Type of Occupancy : EDUCATIONAL
3. Type of Case : NEW
4. Details of previous NOC : NIL
5. Fire Safety Directives letter No : OTE OF EDN. Letter dated 01.03.2011
6. Date of Inspection : 03.09.2012
7. Name of the Inspecting Officer : RAJAN WADEHRA, ADO/M.Rd.
8. Name and designation of the Officers from the building side : Smt. SUSHILA MONIKA EKKA, Principal.
9. Year of Construction : 2011 (Gd + One upper floor)
10. Applicant's letter No. : Nil dt. 12/7/2012

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mts.	9 mts	MR
	• Gate width	Reqd.	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase			
	➤ Upper floors	1	2	MR
	➤ Basement	NA	NA	NA
	• Width of Staircase			
	➤ Upper floors	1.50 mts	1.70 mts each	MR
	➤ Basement	NA	NA	NA
	• Protection of Exits	NA		
	➤ Upper floors	/		
	➤ Basement	/		
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size	1.0 mts	1.15 mts	MR

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			NA
4	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour		NA
		12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	One/300 m ²	6 Nos	MR
		ABC/CO ₂	ABC	MR
		ISI mark	ISI mark	MR
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	<u> </u> /Per Floor		NA
		30 m		
		5mm		
7	Automatic Fire Detection and Alarming System			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 			NA
8	MOEFA	Required	Provided	MR
9	Public Address System			
				NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			NA
11	Internal Hydrant			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 			NA
12	Yard Hydrant			
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 			NA

13	Pumping Arrangements		
	Ground Level	NA	
	➤ Number of main pump		
	➤ Discharge of main pump		
	➤ Head of main pump		
	➤ Jockey pump out put		
	➤ Jockey pump Head		
	➤ Standby pump out put		
	➤ Standby Pump Head		
	➤ Auto Starting/Manual stopping		
	➤ Pump House Access		
	Terrace level	NA	
	➤ Discharge of pump		
	➤ Head of the pump		
	➤ Power Supply		
	➤ Auto starting /Manual stopping		
14	Captive Water Storage for Fire Fighting	NA	
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead tank capacity 		
15	Exit Signage		NA
16	Provision of Lifts		NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 		
17	Standby Power Supply		
18	Refuge Area	NA	
	<ul style="list-style-type: none"> • Total Area • Location 		
19	Fire Control Room		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery back up • Building Floor Plans 		

