

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ *School/3755*

Dated:- *12/10/12*

FIRE SAFETY CERTIFICATE

Certified that the *Bapa Ashram Residential Primary School*  
*Kingsway Camp Delhi* ..... comprised of *Ground floor*  
*only* ..... owned/occupied by *Hari Jan*  
*Sevak Singh* ..... Complied with the fire prevention and fire  
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and  
verified by the officer concerned of Fire Service on *03/8/12* ..... in the presence of  
*Ch. Kaziram* ..... and that the building/premises is fit for occupancy  
*Educational* ..... building with effect from *12/10/12* ..... for a period of  
*03 years* ..... in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on *12/10/12* ..... at New Delhi.

Copy to:-

1 *The Principal*  
*Bapa Ashram Residential*  
*Primary school, K-Camp*  
*Delhi*

2 .....  
.....  
.....

*11/10*  
Chief Fire Officer  
Delhi Fire Service

*[Signature]*

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

11/N

**INSPECTION REPORT**

1. Name & address of the building : Bapa Ashram Residential Primary School, Kingway Camp - Delhi.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No : Circular, Dir. Edun.
6. Date of inspection : 03-8-2012
7. Name of the Inspecting Officers : ADO-SHYAM LAZ
8. Name and designation of officers from the building side : Sh. Kozimal (Caretaker)
9. Year of Construction : 1973 (Ground floor only)
10. Applicant's letter No. : Nil dated 28-6-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular Dir. of Edun. Requirement</u>	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>9 m</u> ✓	<u>MIR</u>
	• Gate width	<u>Accessible</u>	<u>5 M</u> ✓	<u>MIR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	• Upper Floors	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	b. Width of staircases	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	• Upper Floors	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	• Basements	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	c. Protection of exits	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	• Fire check door	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	• Pressurization	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	e. No. of continuous staircases to terrace	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	g. Width of Corridor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	h. Door Size	<u>1 m</u>	<u>1.12 m</u>	<u>MIR</u>

# BAR Pori. School

3	<b>Compartmentation.</b>			
	• Fire check door	NIR	<del>NIP</del>	N/A
	• Sealing of electrical shafts	NIR	<del>NIP</del>	N/A
	• Fire Rating of shaft door	NIR	<del>NIP</del>	N/A
	• Water Curtain	NIR	<del>NIP</del>	N/A
	• Fire Dampers	NIR	<del>NIP</del>	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NIR	N/A
	• Upper floors	12 a/c per hour	NIR	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	2	✓ Provided	NIR
	• Types	ABC	Provided	NIR
	• IS marking	ISI marked	yes	NIR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NIR	<del>NIP</del>	N/A
	• Length of hose reel hose	30 m NIR	<del>NIP</del>	N/A
	• Nozzle diameter	5 mm NIR	<del>NIP</del>	N/A
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NIR	<del>NIP</del>	N/A
	• Location of Main Panel	NIR	<del>NIP</del>	N/A
	• Location of Repeater Panel	NIR	<del>NIP</del>	N/A
	• Alternate source of power	NIR	<del>NIP</del>	N/A
	• Hooters' Location	NIR	<del>NIP</del>	N/A
8	<b>MOEFA</b>	NIR	<del>NIP</del>	N/A
9	<b>Public Address System.</b>	NIR	<del>NIP</del>	N/A
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NIR	<del>NIP</del>	N/A

# B A R Pri School

	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NIR	NIP	N/A
		NIR	NIP	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NIR	NIP	N/A
		NIR	NIP	N/A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> </ul>	NIR	NIP	N/A
		NIR	NIP	N/A

B A R Pri. School.

	➤ Fire service inlet	NIR	NIP	N/A
	➤ Access to tank	NIR	NIP	N/A
	• Overhead Tank capacity	NIR	NIP	N/A
15	Exit Signage.	NIR	NIP	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NIR	NIP	N/A
	• Pressurization of Lift lobby	NIR	NIP	N/A
	• Communication In lift Car	NIR	NIP	N/A
	• Fireman's Grounding Switch	NIR	NIP	N/A
	• Lift Signage	NIR	NIP	N/A
17	Standby power supply	NIR	NIP	N/A
18	Refuge Area.			
	➤ Total Area	NIR	NIP	N/A
	➤ Location	NIR	NIP	N/A
19	Fire Control Room			
	• Detector System Panel	NIR	NIP	N/A
	• Flow Switch Panel	NIR	NIP	N/A
	• PA System Panel	NIR	NIP	N/A
	• Batter backup	NIR	NIP	N/A
	• Building Floor Plans	NIR	NIP	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

aw/Defo

Pl. speak on circular

ADP/NI/... spoken ps...

Shy Lal  
4/8/2012  
(SHYAM LAZ)  
Assist. Dir. officer