

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ *school/3752*

Dated:- *12/10/12*

FIRE SAFETY CERTIFICATE

Certified that the *M.C.D. Primary Boys School, New Chandrawal*
Delhi located at *New Chandrawal*
..... comprised of *Ground floor only* occupied
by *M.C.D. Primary School* was issued NOC vide this office letter
No. *F.6/DFS/MS/2009/1815* Dated *30/6/2009* .. The premises was re-inspected by the
officer concerned of this department on *03-8-12* and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the Director of Education
circular Dated:-01/03/2011 and the building/premises is fit for occupancy Class
Educational with effect from *12/10/12* for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *12/10/12* at New Delhi.

[Signature]
11/10
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. *The Principal,*
M.C.D. Primary Boys School,
New Chandrawal
Delhi.
2. *The Addl. Director Edu.*
North MCD Civic Circle
Minto Road
New Delhi.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : MCD Primary Boys school, New Chandrawal, Delhi-
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFS/MS/09 Dated: 30-6-2009
5. Fire Safety directives letter No : Circular Dir. Edun.
6. Date of inspection : 03-8-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAZ
8. Name and designation of officers from the building side : Principal (Mrs. Sumitra.)
9. Year of Construction : 1959 (Sheds)
10. Applicant's letter No. : Nil dated 18.7.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	^{Circular} NBC of Dir. Edun. Requirement	Provided at site	Remarks MR/NMR
1	Access to building	(old case)		
	• Road width	Accessible	5 m	N/A
	• Gate width	Accessible	3 m	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits	N/A	N/A	N/A
a.	Number of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
b.	Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
c.	Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
e.	No. of continuous staircases to terrace	N/A	N/A	N/A
g.	Width of Corridor	N/A	N/A	N/A
h.	Door Size	1 m	1.10 m	N/A

MCD Pri. Boys School
New Chandrawal, Delhi

3	Compartmentation.			
	• Fire check door	NIR	NIP	N/A
	• Sealing of electrical shafts	NIR	NIP	N/A
	• Fire Rating of shaft door	NIR	NIP	N/A
	• Water Curtain	NIR	NIP	N/A
	• Fire Dampers	NIR	NIP	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	NIP	N/A
	• Upper floors	12 a/c per hour	NIP	N/A
5	Fire Extinguishers			
	• Total numbers	2	2	NIR
	• Types	ABC	provided	NIR
	• IS marking	ISI marked	yes	NIR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NIR	NIP	N/A
	• Length of hose reel hose	30 m	NIR	NIP
	• Nozzle diameter	5 mm	NIR	NIP
7	Automatic fire detection and alarming system.			
	• Type of detectors	NIR	NIP	N/A
	• Location of Main Panel	NIR	NIP	N/A
	• Location of Repeater Panel	NIR	NIP	N/A
	• Alternate source of power	NIR	NIP	N/A
	• Hooters' Location	NIR	NIP	N/A
8	MOEFA	NIR	NIP	N/A
9	Public Address System.	NIR	NIP	N/A
10	Automatic Sprinkler System.	1		
	• Basement	NIR	NIP	N/A

	<ul style="list-style-type: none"> • Upper Floor 	NIR	N/P	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NIR	N/P	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NIR	N/P	N/A
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NIR	N/P	N/A
	<ul style="list-style-type: none"> • Hose Box 	NIR	N/P	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	NIR	N/P	N/A
	<ul style="list-style-type: none"> • Hose Box 	NIR	N/P	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 			
	<ul style="list-style-type: none"> ➤ Pump House Access 	NIR	N/P	N/A
	<ul style="list-style-type: none"> • Terrace level 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Head of the pump 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Power Supply 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NIR	N/P	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	NIR	N/P	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NIR	N/P	N/A

MCD Primary Boys School,
New Chandrawal, Delhi

	➤ Fire service inlet	NIR	NIP	N/A
	➤ Access to tank	NIR	NIP	N/A
	• Overhead Tank capacity	NIR	NIP	N/A
15	Exit Signage.	NIR	NIP	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NIR	NIP	N/A
	• Pressurization of Lift lobby	NIR	NIP	N/A
	• Communication In lift Car	NIR	NIP	N/A
	• Fireman's Grounding Switch	NIR	NIP	N/A
	• Lift Signage	NIR	NIP	N/A
17	Standby power supply	NIR	NIP	N/A
18	Refuge Area.			
	➤ Total Area	NIR	NIP	N/A
	➤ Location	NIR	NIP	N/A
19	Fire Control Room			
	• Detector System Panel	NIR	NIP	N/A
	• Flow Switch Panel	NIR	NIP	N/A
	• PA System Panel	NIR	NIP	N/A
	• Batter backup	NIR	NIP	N/A
	• Building Floor Plans	NIR	NIP	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

~~DO~~ DO (NW)

12 speaker in speaker pl. AS directed complete the format

Shyam Lal
04/8/2012
(SHYAM LAL)
Asstt. Divn. Officer